



MANUFACTURER'S DECLARATION OF CONFORMITY

We:

Pepperl+Fuchs SE

Lilienthalstraße 200 68307 Mannheim Germany

declare under our own responsibility that the product(s):

VIM3*PP-*D*-*IO-*

IO-Link Device

See details in Annex - Conform products

to which this declaration refers conform to:

- Additional conformance to Device Profiles (If checked refer to Part A on page 2)
- Conformance exceptions
 (If checked refer to Part B on page 2)

The conformity tests are documented in the test report(s):

PRDE-D4C8

Issued at Mannheim, 2024-09-10

Authorized signatory

Name: i.V. Stefan Horvatic

Shu Vanchiz

Title: Manager Innovation Unit Encoder

i.V. Christian Güntert

Manager Product Management Encoder

With

MD-Version: V1.1.3 / 2024-05

Reproduction and all distribution without written authorization prohibited

NOTE 1 Relevant Test specification is V1.1.3, January 2021

NOTE 2 Additional validity in Package 2020 and Corrigendum

Part A - Additional conformance to Device Profiles

	Specification
\boxtimes	IO-Link Common Profile Specification, V1.2, Jan. 2024
	IO-Link Common Profile Specification, V1.1, Dec. 2021
\boxtimes	IO-Link Profile BLOB Transfer & Firmware Update Specification, V1.1, Sept. 2019
	IO-Link Smart Sensors 2 nd Edition Specification, V1.2, Jan. 2024
	IO-Link Smart Sensors 2 nd Edition Specification, V1.1, Sept. 2021

Part B - Conformance exceptions

We herewith declare the following deviations to the related specifications	Reason
Power-on wake-up readiness delay according to Exception 24-01	This Device may delay the communication up to 3.6 s after power-on. This may result in failure reactions of the system following power-on.

Annex - Conform products

Affilex - Comorni products		
Product name	Device ID	
VIM3'm'PP-E'f'DC8-0RE-IO-1V14'p'	5308673 (0x510101) 5308927 (0x5101FF)	
Key: 'm': 2, 4, D 'f': 0 9, A Z 'p': 01 99		