



Certificate of Compliance

Certificate: 80140625

Master Contract: 221913

Project: 80140625

Date Issued: September 2, 2022

Issued To: Pepperl+Fuchs SE
 Lilienthalstrasse 200
 Mannheim , Baden-Württemberg 68307
 Germany

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Maria Gomes
 Maria Gomes

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations– Certified to U.S. Standards

Class I, Division 2, Groups A, B, C and D, T6...T3:

Product	Vibration Level Switch, series LVL-M3 - h k lll i - d e f g b c - aa XX .XXXX	
	Where	
	aa (approval)	= CC
	b (output)	= E, W,N
	c (display; operation)	= A
	d (housing; material)	= A
	e (electrical conn.)	= B, F, I
	f (application)	= A
	g (surface finish)	= A
	h (probe version)	= A, C, B
	i (probe length; mat.)	= 1 alphanumeric characters (not relevant for safety)
	k (process conn.)	= 1 alphanumeric characters (not relevant for safety)
lll (process conn. size)	= 3 alphanumeric characters (not relevant for safety)	
+	(additional options; any number of each of the following options may be chosen)	



Certificate: 80140625
Project: 80140625

Master Contract: 221913
Date Issued: September 2, 2022

	xx (services) = 2 alphanumeric characters (not relevant for safety) xx (test; Certificate) = 2 alphanumeric characters (not relevant for safety) xx (additional approvals) = 2 alphanumeric characters (not relevant for safety) xx (accessories mounted) = 2 alphanumeric characters (not relevant for safety) xx (accessories enclosed) = WP; or 2 alphanumeric characters (not relevant for safety) xx (marking) = 2 alphanumeric characters (not relevant for safety) Note: Some option codes may be restricted for certain model types.
Electrical Rating (b)	Dependent on Output option, bb: E (FEL42): 10...55Vdc, 350 mA; W (FEL44): 19...253 Vac, 25VA, 50/60Hz or 19...55Vdc, 1.3W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A N (FEL48): 8.2Vdc, NAMUR
Enclosure Rating	Type 4X/6P, IP66/68
Temp. code and ambient/process temperature	T6...T3 with standard Ta of -40°C to + 70°C and process temperature -40°C to +150°C; refer to installation drawing for specific T-code and limitations of temperature ranges
MWP/Process Seal	580 psi (40 bar) Single Seal
Installation Drawing	SI01804O

Product	Vibration Level Switch, series LVL-M4 - h k lll i - d e f g b c -aa XX .XXXX Where aa (approval) = CC, CD b (output) = A, E, B, N, M c (display; operation) = A, B d (housing; material) = A, G, D e (electrical conn.) = B, C, and F (aa=CC only), I (aa=CC and CD) f (application) = A, B, C g (surface finish) = A h (probe version) = A, C, B i (probe length; mat.) = 1 alphanumeric characters (not relevant for safety) k (process conn.) = 1 alphanumeric characters (not relevant for safety) lll (seal) = 3 alphanumeric characters (not relevant for safety) + (additional options; xx (Applic. Package) = 1 alphanumeric characters (not relevant for safety) xx (services) = 2 alphanumeric characters (not relevant for safety) xx (test; Certificate) = U1, U2; or 2 alphanumeric characters (not relevant for safety) xx (additional approvals) = 2 alphanumeric characters (not relevant for safety) xx (sensor design) = TD, DF, M9 xx (accessories mounted) = BL, VB, O9 xx (accessories enclosed) = WS, WP, ST, XX xx (marking) = 2 alphanumeric characters (not relevant for safety) Note: Some option codes may be restricted for certain model types.
Electrical Rating	Dependent on option b (output): A (FEL61): 19...253 Vac, 2VA, 50/60Hz E (FEL62): 10...55Vdc, 350 mA



Certificate: 80140625
Project: 80140625

Master Contract: 221913
Date Issued: September 2, 2022

	<p>B (FEL64DC): 9...20Vdc, 1W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A</p> <p>N (FEL64): 19...253 Vac, 25VA, 50/60Hz or 19...55Vdc, 1.3W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A</p> <p>M (FEL68): 8.2Vdc, NAMUR</p>
Enclosure Rating	Type 4X/6P, IP66/68
Temp. code and ambient/process temperature	T6...T3 with standard Ta of -40°C to + 70°C (-50°C to + 70°C, where option xx=U1; -52°C to + 70°C, where option xx=U2) and process temperature -50°C to +150°C; refer to installation drawing for specific T-code and extensions/limitations of temperature ranges.
MWP/Process seal	<p>Dependent on option f (application):</p> <p>A: 928 psi (64 bar)</p> <p>B: 1450 psi (100 bar)</p> <p>C: 362 psi (25 bar)</p> <p>Single Seal</p>
Installation Drawing	SI01814O (aa = CC) or SI01815O (aa = CD)

Class I, Division 1, Groups A, B, C, D T6...T3
Ex db IIC T6...T3 Ga/Gb
Class I, Zone 0/1, AEx db IIC T6...T3 Ga/Gb

Product	<p>Vibration Level Switch, series LVL-M3- h k lll i - d e f g b c - aa XX .XXXX</p> <p>Where</p> <p>aa (approval) = CX</p> <p>b (output) = E, W, N</p> <p>c (display; operation) = A</p> <p>d (housing; material) = A</p> <p>e (electrical conn.) = I</p> <p>f (application) = A</p> <p>g (surface finish) = A</p> <p>h (probe version) = A, C, B</p> <p>i (probe length; mat.) = 1 alphanumeric characters (not relevant for safety)</p> <p>k (process conn.) = 1 alphanumeric characters (not relevant for safety)</p> <p>lll (process conn. size) = 3 alphanumeric characters (not relevant for safety)</p> <p>+ (additional options; any number of each of the following options may be chosen)</p> <p>xx (services) = 2 alphanumeric characters (not relevant for safety)</p> <p>xx (test; Certificate) = 2 alphanumeric characters (not relevant for safety)</p> <p>xx (additional approvals) = 2 alphanumeric characters (not relevant for safety)</p> <p>xx (accessories mounted) = 2 alphanumeric characters (not relevant for safety)</p> <p>xx (accessories enclosed) = WP; or 2 alphanumeric characters (not relevant for safety)</p> <p>xx (marking) = 2 alphanumeric characters (not relevant for safety)</p> <p>Note: Some option codes may be restricted for certain model types.</p>
Electrical Rating	<p>Dependent on Output option, bb:</p> <p>E (FEL42): 10...55Vdc, 350 mA;</p> <p>W (FEL44): 19...253 Vac, 25VA, 50/60Hz or 19...55Vdc, 1.3W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A</p> <p>N (FEL48): 8.2Vdc, NAMUR</p>



Certificate: 80140625
Project: 80140625

Master Contract: 221913
Date Issued: September 2, 2022

Enclosure Rating	Type 4X/6P, IP66/68
Temp. code and ambient/process temperature	T6...T3 with standard Ta of -40°C to + 70°C and process temperature -40°C to +150°C; refer to installation drawing for specific T-code and limitations of temperature ranges
MWP/Process Seal	580 psi (40 bar) Single Seal
Installation Drawing	SI018050

Class I, Division 1, Groups A,B,C,D; Class II, Division 1, Groups E,F,G: Class III T6...T3
Ex db IIC T6...T3 Ga/Gb
Class I, Zone 0/1, AEx db IIC T6...T3 Ga/Gb

Product	<p>Vibration Level Switch, series LVL-M4- h k lll i - d e f g b c -aa XX .XXXX</p> <p>Where</p> <ul style="list-style-type: none"> aa (approval) = CD b (output) = A, E, B, N, M c (display; operation) = A, B d (housing; material) = A, G, D e (electrical conn.) = I f (application) = A, B, C g (surface finish) = A h (probe version) = A, C, B i (probe length; mat.) = 1 alphanumeric characters (not relevant for safety) k (process conn.) = 1 alphanumeric characters (not relevant for safety) lll (seal) = 3 alphanumeric characters (not relevant for safety) + (additional options; xx (Applic. Package) = 1 alphanumeric characters (not relevant for safety) xx (services) = 2 alphanumeric characters (not relevant for safety) xx (test; Certificate) = U1, U2; or 2 alphanumeric characters (not relevant for safety) xx (additional approvals) = 2 alphanumeric characters (not relevant for safety) xx (sensor design) = TD, DF, M9 xx (accessories mounted) = BL, VB, O9 xx (accessories enclosed) = WS, WP, ST, XX xx (marking) = 2 alphanumeric characters (not relevant for safety) <p>Note: Some option codes may be restricted for certain model types.</p>
Electrical Rating	<p>Dependent on option bb (output):</p> <ul style="list-style-type: none"> A (FEL61): 19...253 Vac, 2VA, 50/60Hz E (FEL62): 10...55Vdc, 350 mA B (FEL64DC): 9...20Vdc, 1W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A N (FEL64): 19...253 Vac, 25VA, 50/60Hz or 19...55Vdc, 1.3W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A M (FEL68): 8.2Vdc, NAMUR
Enclosure Rating	Type 4X/6P, IP66/68



Certificate: 80140625
Project: 80140625

Master Contract: 221913
Date Issued: September 2, 2022

Temp. code and ambient/process temperature	T6...T3 with standard Ta of -40°C to + 70°C (-50°C to + 70°C, where option xx=U1; -52°C to + 70°C, where option xx=U2) and process temperature -50°C to +150°C; refer to installation drawing for specific T-code and extensions/limitations of temperature ranges.
MWP/Process seal	Dependent on option f (application): A: 928 psi (64 bar) B: 1450 psi (100 bar) C: 362 psi (25 bar) Single Seal
Installation Drawing	SI018150

Conditions of Acceptability:

- The flameproof joints are not intended to be repaired.
- The Vibration Level Switch shall be installed and maintained such that hazards caused by electrostatic discharge are excluded.
- Limit switches with the following modules, to be supplied by a Class 2 or Limited Energy Source in accordance with CSA 61010-1-12: FEL42, FEL48, FEL62, FEL64DC, FEL68.

- CLASS 2258 04** - PROCESS CONTROL EQUIPMENT - Intrinsically Safe Entity - For Hazardous Locations
- CLASS 2258 84** - PROCESS CONTROL EQUIPMENT - Intrinsically Safe Entity - For Hazardous Locations– Certified to U.S. Standards

Class I, Division 1, Groups A, B, C and D T6...T3

Ex ia IIC T6...T3 Ga

Class I, Zone 0 AEx ia IIC T6...T3 Ga

Product	Vibration Level Switch, series LVL-M3 - h k lll i - d e f g b c - aa XX .XXXX Where aa (approval) = CH b (output) = N c (display; operation) = A d (housing; material) = P, A, e (electrical conn.) = A, B, F, H, I, M f (application) = A g (surface finish) = A h (probe version) = A, C, B i (probe length; mat.) = 1 alphanumeric characters (not relevant for safety) k (process conn.) = 1 alphanumeric characters (not relevant for safety) lll (process conn. size) = 3 alphanumeric characters (not relevant for safety) + (additional options; any number of each of the following options may be chosen) xx (services) = 2 alphanumeric characters (not relevant for safety) xx (test; Certificate) = 2 alphanumeric characters (not relevant for safety) xx (additional approvals) = 2 alphanumeric characters (not relevant for safety) xx (accessories mounted) = 2 alphanumeric characters (not relevant for safety) xx (accessories enclosed) = WP; or 2 alphanumeric characters (not relevant for safety)
---------	---



Certificate: 80140625
Project: 80140625

Master Contract: 221913
Date Issued: September 2, 2022

	xx (marking) = 2 alphanumeric characters (not relevant for safety) Note: Some option codes may be restricted for certain model types.
Electrical Rating	Dependent on Output option, b: I.S. connection parameters are defined in the below table N (FEL48): 8.2Vdc, NAMUR
Enclosure Rating	Type 4X/6P, IP66/68
Temp. code and ambient/process temperature	T6...T3 with standard Ta of -40°C to + 70°C; (0°C to + 70°C, where option d = P) and process temperature -40°C to +150°C; refer to installation drawing for specific T-code and limitations of temperature ranges
MWP/Process Seal	580 psi (40 bar) Single Seal
Installation Drawing	Intrinsically safe when installed per SI018030

I.S. Connections Parameters for LVL-M3-CH...:

Output code “b”	N (FEL48)
Input X100 (Power)	Ui = 16 V Ii = 52 mA Pi =170 mW Ci = 30 nF Li = N/A μH

Product	<p>Vibration Level Switch, series LVL-M4- h k lll i - d e f g b c -aa XX .XXXX Where</p> <ul style="list-style-type: none"> aa (approval) = CI b (output) = M c (display; operation) = A, B d (housing; material) = P e (electrical conn.) = A, B, C, F, H, I, M f (application) = A, B, C g (surface finish) = A h (probe version) = A, C, B i (probe length; mat.) = 1 alphanumeric characters (not relevant for safety) k (proc. conn. seal surf.) = 1 alphanumeric characters (not relevant for safety) lll (proc. Conn. size) = 3 alphanumeric characters (not relevant for safety) + (additional options; xx (Applic. Package) = 1 alphanumeric characters (not relevant for safety) xx (services) = 2 alphanumeric characters (not relevant for safety) xx (test; Certificate) = 2 alphanumeric characters (not relevant for safety) xx (additional approvals) = 2 alphanumeric characters (not relevant for safety) xx (sensor design) = TD, DF, M9 xx (accessories mounted) = BL, VB, O9 xx (accessories enclosed) = WS, WP, ST, XX xx (marking) = 2 alphanumeric characters (not relevant for safety) <p>Note: Some option codes may be restricted for certain model types.</p>
---------	--



Certificate: 80140625
Project: 80140625

Master Contract: 221913
Date Issued: September 2, 2022

Electrical Rating	Dependent on option bb (output): I.S. connection parameters are defined in the below table M (FEL68): 8.2Vdc, NAMUR
Enclosure Rating	Type 4X/6P, IP66/68
Temp. code and ambient/process temperature	T6...T3 with standard Ta of 0°C to +70°C and process temperature -50°C to +150°C; refer to installation drawing for specific T-code and extensions/limitations of temperature ranges. (T-code is restricted to T4...T3 with Bluetooth incl. Battery, option VB)
MWP/Process seal	Dependent on option f (application): A: 928 psi (64 bar) B: 1450 psi (100 bar) C: 362 psi (25 bar) Single Seal
Installation Drawing	Intrinsically safe when installed per SI018130.

I.S. Connections Parameters for LVL-M4-CI

Output code "bb"	M (FEL68)
Input X100 (Power)	Ui = 16 V Ii = 52 mA Pi = 170 mW Ci = 30 nF Li = N/A μH

Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; Class III T6...T3
Ex ia IIC T6...T3 Ga
Class I, Zone 0, AEx ia IIC T6...T3 Ga

Product	Vibration Level Switch, series LVL-M4- h k lll i - d e f g b c -aa XX .XXXX Where aa (approval) = CI b (output) = M c (display; operation) = A, B d (housing; material) = A, G, D e (electrical conn.) = A, B, C, F, I, M f (application) = A, B, C g (surface finish) = A h (probe version) = A, C, B i (probe length; mat.) = 1 alphanumeric characters (not relevant for safety) k (proc. conn. seal surf.) = 1 alphanumeric characters (not relevant for safety) lll (proc. Conn. size) = 3 alphanumeric characters (not relevant for safety) + (additional options; xx (Applic. Package) = 1 alphanumeric characters (not relevant for safety) xx (services) = 2 alphanumeric characters (not relevant for safety) xx (test; Certificate) = U1, or 2 alphanumeric characters (not relevant for safety)
---------	---



Certificate: 80140625
Project: 80140625

Master Contract: 221913
Date Issued: September 2, 2022

	xx (additional approvals) = 2 alphanumeric characters (not relevant for safety) xx (sensor design) = TD, DF, M9 xx (accessories mounted) = BL, VB, O9 xx (accessories enclosed) = WS, WP, ST, XX xx (marking) = 2 alphanumeric characters (not relevant for safety) Note: Some option codes may be restricted for certain model types.
Electrical Rating	Dependent on option bb (output): I.S. connection parameters are defined in the below table M (FEL68): 8.2Vdc, NAMUR
Enclosure Rating	Type 4X/6P, IP66/68
Temp. code and ambient/process temperature	T6...T3 with standard Ta of -40°C to + 70°C (-50°C to + 70°C, where option xx=U1; and process temperature -50°C to +150°C; refer to installation drawing for specific T-code and extensions/limitations of temperature ranges. (T-code is restricted to T4...T3 with Bluetooth incl. Battery, option VB)
MWP/Process seal	Dependent on option f (application): A: 928 psi (64 bar) B: 1450 psi (100 bar) C: 362 psi (25 bar) Single Seal
Installation Drawing	Intrinsically safe when installed per SI018130

I.S. Connections Parameters for LVL-M4-CI

Output code "bb"	M (FEL68)
Input X100 (Power)	Ui = 16 V Ii = 52 mA Pi = 170 mW Ci = 30 nF Li = N/A μH

Conditions of Acceptability:

- The Vibration Level Switch shall be installed and maintained such that hazards caused by electrostatic discharge are excluded.
- For Vibration Level Switch with an aluminium enclosure, when used as EPL Ga equipment, shall be installed in such a way that, even in the event of rare incidents, ignition sources due to impact and friction between the enclosure and iron or steel are excluded.

CLASS 2252 06 - PROCESS CONTROL EQUIPMENT
CLASS 2252 86 - PROCESS CONTROL EQUIPMENT (Certified to U.S. Standards)

Product	Vibration Level Switch, series LVL-M3 - h k lll i - d e f g b c - aa XX .XXXX Where aa (approval) = CG b (output) = E, W, N c (display; operation) = A d (housing; material) = P, A
---------	---



Certificate: 80140625
Project: 80140625

Master Contract: 221913
Date Issued: September 2, 2022

	<p>e (electrical conn.) = A, B, F, G, H, I, M f (application) = A g (surface finish) = A h (probe version) = A, C, B i (probe length; mat.) = 1 alphanumeric characters (not relevant for safety) k (process conn.) = 2 alphanumeric characters (not relevant for safety) lll (process conn. size) = 3 alphanumeric characters (not relevant for safety) + (additional options; any number of each of the following options may be chosen) xx (services) = 2 alphanumeric characters (not relevant for safety) xx (test; Certificate) = 2 alphanumeric characters (not relevant for safety) xx (additional approvals) = 2 alphanumeric characters (not relevant for safety) xx (accessories mounted) = 2 alphanumeric characters (not relevant for safety) xx (accessories enclosed) = WP; or 2 alphanumeric characters (not relevant for safety) xx (marking) = 2 alphanumeric characters (not relevant for safety)</p> <p>Note: Some option codes may be restricted for certain model types.</p>
Electrical Rating	<p>Dependent on Output option, b: E (FEL42): 10...55Vdc, 350 mA; W (FEL44): 19...253 Vac, 25VA, 50/60Hz or 19...55Vdc, 1.3W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A N (FEL48): 8.2Vdc, NAMUR</p>
Enclosure Rating	Type 4X/6P, IP66/68
Ambient/process temperature	Standard Ta of -40°C to +70°C. ; (0°C to +70°C, where option d = P) Process temperature -40°C to +150°C;
MWP	580 psi (40 bar)

Product	<p>Vibration Level Switch, series LVL-M4- h k lll i - d e f g b c - aa XX .XXXX</p> <p>Where</p> <p>aa (approval) = CG b (output) = A, E, B, N, M c (display; operation) = A, B d (housing; material) = P, A, G, D e (electrical conn.) = A, B, C, F, G, H, I, M f (application) = A, B, C g (surface finish) = A h (probe version) = A, C, B i (probe length; mat.) = 1 alphanumeric characters (not relevant for safety) k (process conn.) = 1 alphanumeric characters (not relevant for safety) lll (seal) = 3 alphanumeric characters (not relevant for safety) + (additional options; any number of each of the following options may be chosen) xx (Applic. Package) = 1 alphanumeric characters (not relevant for safety) xx (services) = 2 alphanumeric characters (not relevant for safety) xx(test; Certificate) = U1, U2; or 2 alphanumeric characters (not relevant for safety) xx (additional approvals) = 2 alphanumeric characters (not relevant for safety) xx (sensor design) = TD, DF, M9 xx (accessories mounted) = BL, VB, O9</p>
---------	---



Certificate: 80140625
Project: 80140625

Master Contract: 221913
Date Issued: September 2, 2022

	xx (accessories enclosed) = WS, WP, ST, XX xx (marking) = 2 alphanumeric characters (not relevant for safety) Note: Some option codes may be restricted for certain model types.
Electrical Rating	Dependent on option b (output): A (FEL61): 19...253 Vac, 2VA, 50/60Hz E (FEL62): 10...55Vdc, 350 mA B (FEL64DC): 9...20Vdc, 1W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A N (FEL64): 19...253 Vac, 25VA, 50/60Hz or 19...55Vdc, 1.3W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A M (FEL68): 8.2Vdc, NAMUR
Enclosure Rating	Type 4X/6P, IP66/68
Ambient/process temperature	Standard Ta of -40°C to +70°C; -50°C to +70°C, where option xx=U1; -52°C to +70°C, where option xx=U2 ; 0°C to +70°C, where option d = A Process temperature -50°C to +150°C.
MWP	Dependent on option f (application): A: 928 psi (64 bar) B: 1450 psi (100 bar) C: 362 psi (25 bar)

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0-20	General requirements — Canadian Electrical Code, Part II
C22.2 No. 25-17	Enclosures for use in Class II, Division 1, Groups E, F, and G hazardous locations
C22.2 No. 30-M1986 (r2016)	Explosion-proof enclosures for use in Class I hazardous locations
C22.2 No. 30-20 ¹⁾	Explosion-proof Equipment
CSA C22.2 No. 94.2-15	Enclosures for Electrical Equipment, Environmental Considerations
CAN/CSA-C22.2 No. 60529:2016	Degrees of protection provided by enclosures (IP Code)
CAN/CSA-C22.2 No. 61010-1-12	Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements
CAN/CSA-C22.2 No. 60079-0:19	Explosive atmospheres – Part 0: Equipment – General requirements
CAN/CSA-C22.2 No. 60079-1:16	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures “d”
CAN/CSA-C22.2 No. 60079-11:14	Explosive atmospheres – Part 11: Equipment protection by intrinsic safety “i”
CAN/CSA-C22.2 No. 60079-26:16	Explosive atmospheres – Part 26: Equipment with Equipment Protection Level (EPL) Ga
CAN/CSA C22.2 No. 213-17	Non-incendive Electrical Equipment for Use in Class I and II, Division 2, and Class III Hazardous (Classified) Locations
IEC 60529: 2013, Edition 2.2	Degrees of protection provided by enclosures (IP Code)
UL 61010-1-Third Edition	Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements
FM3600-2018	Approval Standard for Electrical Equipment for Use in Hazardous (Classified) Locations - General Requirements



Certificate: 80140625
Project: 80140625

Master Contract: 221913
Date Issued: September 2, 2022

FM3610-2018	Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II and III, Division 1, Hazardous (Classified) Locations
FM3615-2018	Approval Standard for Explosionproof Electrical Equipment General Requirements
FM3616-2011	Approval Standard for Dust-Ignitionproof Electrical Equipment General Requirements
UL 50E-15, Second Edition	Enclosures for Electrical Equipment, Environmental Considerations
UL 60079-0-2019, Seventh Edition	Explosive atmospheres – Part 0: Equipment – General requirements
UL 60079-1-2015, Seventh Edition	Explosive Atmospheres – Part 1: Equipment Protection by Flameproof Enclosures “d”
UL 60079-11-2014, Sixth Edition	Explosive Atmospheres – Part 11: Equipment Protection by Intrinsic Safety “i”
UL-60079-26: Third Edition	Explosive atmospheres – Part 26: Equipment with Equipment Protection Level (EPL) Ga
UL 121201-2017, Ninth Edition	Non-incendive Electrical Equipment for Use in Class I and II, Division 2, and Class III Hazardous (Classified) Locations
ANSI/UL 122701- 2017, Third Edition	Requirements for Process Sealing Between Electrical Systems and Flammable or Combustible Process Fluids

1) This standard is applicable for the new XP model FTL64 probe only

MARKINGS

Each unit shall bear all the required markings identified in the applicable certification report(s).

Note: The Listee’s name and/or CSA file number shall replace the submittor’s equivalent information (where applicable).



Supplement to Certificate of Compliance

Certificate: 80140625

Master Contract: 221913

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Submitter Report	Submitter Model	Listee Model
80140625	September 2, 2022	151079-80022351	FTL41	LVL-M3
			FTL51B	LVL-M4