Certificate of Compliance

Certificate: 80140625 **Master Contract:** 221913

Project: 80228740 **Date Issued:** January 21, 2025

Issued to: **Pepperl+Fuchs SE**
Lilienthalstrasse 200
Mannheim, Baden-Württemberg 68307
Germany

Attention: **Martin Holdefer**

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Issued by: H. Gambell
H. Gambell

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations
CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations– Certified to U.S. Standards

Class I, Division 2, Groups A, B, C and D, T6…T1:

Product	Liquiphant, LVL-M3- h j kkk i - d e f g b c - aa XX .XXXX where aa (approval) = CC b (output) = E, W, N c (display; operation) = A d (housing; material) = A e (electrical conn.) = B, F, I f (application) = A g (surface finish) = A h (probe version) = A, C, B i (probe length; mat.) = 1 alphanumeric characters (not relevant for safety) j (process conn., sealing) = 1 alphanumeric characters (not relevant for safety) kkk (process conn., size) = 3 alphanumeric characters (not relevant for safety) + (additional options; any number of each of the following options may be chosen) XX (services) = 2 alphanumeric characters (not relevant for safety) XX (test; Certificate) = 2 alphanumeric characters (not relevant for safety) XX (additional approvals) = 2 alphanumeric characters (not relevant for safety)

© 2019 CSA Group. All rights reserved.

	XX (accessories mounted) = 2 alphanumeric characters (not relevant for safety) XX (accessories enclosed) = WP; or 2 alphanumeric characters (not relevant for safety) XX (marking) = 2 alphanumeric characters (not relevant for safety) Note: Some option codes may be restricted for certain model types.
Electrical Rating (bb)	Dependent on Output option, b: E (FEL42): 10…55Vdc, 350 mA; W (FEL44): 19…253 Vac, 25VA, 50/60Hz or 19…55Vdc, 1.3W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A N (FEL48): 8.2Vdc, NAMUR
Enclosure Rating	Type 4X/6P, IP66/68
Temp. code and ambient/process temperature	T6…T3 with standard Ta of -40°C to + 70°C and process temperature -40°C to +150°C; refer to installation drawing for specific T-code and limitations of temperature ranges
MWP/Process Seal	580 psi (40 bar) Single Seal
Installation Drawing	DOCT-8483

Product	Liquiphant, series LVL-M4- h j kkk i – d e f g b c -aa XX .XXXX where aa (approval) = CC b (output) = A, E, B, N, M c (display; operation) = A, B d (housing; material) = A, G, D e (electrical conn.) = B, C, F, H and I f (application) = A, B, C g (surface finish) = A, Y **(**LVL-M4**)** h (probe version) = A, C, B i (probe length; mat.) = 1 alphanumeric characters (not relevant for safety) j (process conn., sealing) = 1 alphanumeric characters (not relevant for safety) kkk (process conn., size) = 3 alphanumeric characters (not relevant for safety) + (additional options; any number of each of the following options may be chosen) XX (operating lang.) = 2 alphanumeric characters (not relevant for safety) XX (Applic. Package) = 2 alphanumeric characters (not relevant for safety) XX (test; Certificate) = U1, U2; or 2 alphanumeric characters (not relevant for safety) XX (additional approvals) = 2 alphanumeric characters (not relevant for safety) XX (sensor design) = TD, DF, M9 XX (accessories mounted) = BL, VB, O9 XX (accessories enclosed) = WS, WP, ST, XX XX (firmware vers.) = 2 alphanumeric characters (not relevant for safety) XX (marking) = 2 alphanumeric characters (not relevant for safety) Note: Some option codes may be restricted for certain model types.
Electrical Rating	Dependent on option b (output): A (FEL61): 19…253 Vac, 2VA, 50/60Hz E (FEL62): 10…55Vdc, 350 mA B (FEL64DC): 9…20Vdc, 1W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A N (FEL64): 19…253 Vac, 25VA, 50/60Hz or 19…55Vdc, 1.3W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A M (FEL68): 8.2Vdc, NAMUR

© 2019 CSA Group. All rights reserved.

Enclosure Rating	Type 4X/6P, IP66/68
Temp. code and ambient/process temperature	<table><tr><td>Temperature Code and Ambient Temperature Range</td><td colspan="2">Extensions/Limitations based on options:</td></tr><tr><td rowspan="2">T6…T3 -40°C to + 70°C</td><td>xx=U1</td><td>min. temp = -50ºC</td></tr><tr><td>xx=U2</td><td>min. temp = -60ºC</td></tr><tr><td colspan="3">Process temperature -50°C to +150°C; refer to installation drawing for specific T-code and additional derating of temperature ranges.</td></tr></table>
MWP/Process seal	Dependent on option f (application): A: 928 psi (64 bar) B: 1450 psi (100 bar) C: 362 psi (25 bar) Single Seal
Installation Drawing	DOCT-8516

Class I, Division 1, Groups A, B, C, D T6…T3
Ex db IIC T6…T3 Ga/Gb
Class I, Zone 0/1, AEx db IIC T6…T3 Ga/Gb

Product	Liquiphant, LVL-M3- h j kkk i - d e f g b c - aa XX .XXXX where aa (approval) = CX b (output) = E, W, N c (display; operation) = A d (housing; material) = A e (electrical conn.) = B, F, I f (application) = A g (surface finish) = A h (probe version) = A, C, B i (probe length; mat.) = 1 alphanumeric characters (not relevant for safety) j (process conn., sealing) = 1 alphanumeric characters (not relevant for safety) kkk (process conn., size) = 3 alphanumeric characters (not relevant for safety) + (additional options; any number of each of the following options may be chosen) XX (services) = 2 alphanumeric characters (not relevant for safety) XX (test; Certificate) = 2 alphanumeric characters (not relevant for safety) XX (additional approvals) = 2 alphanumeric characters (not relevant for safety) XX (accessories mounted) = 2 alphanumeric characters (not relevant for safety) XX (accessories enclosed) = WP; or 2 alphanumeric characters (not relevant for safety) XX (marking) = 2 alphanumeric characters (not relevant for safety) Note: Some option codes may be restricted for certain model types.
Electrical Rating	Dependent on Output option, b: E (FEL42): 10…55Vdc, 350 mA; W (FEL44): 19…253 Vac, 25VA, 50/60Hz or 19…55Vdc, 1.3W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A N (FEL48): 8.2Vdc, NAMUR
Enclosure Rating	Type 4X/6P, IP66/68
Temp. code and ambient/process temperature	T6…T3 with standard Ta of -40°C to + 70°C and process temperature -40°C to +150°C; refer to installation drawing for specific T-code and limitations of temperature ranges

© 2019 CSA Group. All rights reserved.

MWP/Process Seal	580 psi (40 bar) Single Seal
Installation Drawing	DOCT-8485

Class I, Division 1, Groups A,B,C,D; Class II, Division 1, Groups E,F,G: Class III T6…T1
Ex db IIC T6…T1 Ga/Gb
Class I, Zone 0/1, AEx db IIC T6…T1 Ga/Gb

Product

Liquiphant, series LVL-M4- h j kkk i – d e f g b c -aa XX .XXXX

where

aa	(approval)	= CD
b	(output)	= A, E, B, N, M
c	(display; operation)	= A, B
d	(housing; material)	= A, G, D
e	(electrical conn.)	= B, C, F, H and I
f	(application)	= A, B, C
g	(surface finish)	= A, Y **(**LVL-M4**)**
h	(probe version)	= A, C, B
i	(probe length; mat.)	= 1 alphanumeric characters (not relevant for safety)
j	(process conn., sealing)	= 1 alphanumeric characters (not relevant for safety)
kkk	(process conn., size)	= 3 alphanumeric characters (not relevant for safety)
+	(additional options; any number of each of the following options may be chosen)	
XX	(operating lang.)	= 2 alphanumeric characters (not relevant for safety)
XX	(Applic. Package)	= 2 alphanumeric characters (not relevant for safety)
XX	(test; Certificate)	= U1, U2; or 2 alphanumeric characters (not relevant for safety)
XX	(additional approvals)	= 2 alphanumeric characters (not relevant for safety)
XX	(sensor design)	= TD, DF, M9
XX	(accessories mounted)	= BL, VB, O9
XX	(accessories enclosed)	= WS, WP, ST, XX
XX	(firmware vers.)	= 2 alphanumeric characters (not relevant for safety)
XX	(marking)	= 2 alphanumeric characters (not relevant for safety)

Note: Some option codes may be restricted for certain model types.

Electrical Rating

Dependent on option b (output):

A (FEL61):	19…253 Vac, 2VA, 50/60Hz
E (FEL62):	10…55Vdc, 350 mA
B (FEL64DC):	9…20Vdc, 1W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A
N (FEL64):	19…253 Vac, 25VA, 50/60Hz or 19…55Vdc, 1.3W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A
M (FEL68):	8.2Vdc, NAMUR

Enclosure Rating

Type 4X/6P, IP66/68

Temp. code and ambient/process temperature

Temperature Code and Ambient Temperature Range	Extensions/Limitations based on options:	
T6…T3 -40°C to + 70°C	xx=U1	min. temp = -50ºC
	xx=U2	min. temp = -60ºC
Process temperature -50°C to +150°C; refer to installation drawing for specific T-code and additional derating of temperature ranges.		

© 2019 CSA Group. All rights reserved.

MWP/Process seal	Dependent on option f (application): A: 928 psi (64 bar) B: 1450 psi (100 bar) C: 362 psi (25 bar) Single Seal
Installation Drawing	DOCT-8517

Conditions of Acceptability:

- The flameproof joints are not intended to be repaired.
- The Liquid Level Switches Liquiphant shall be installed and maintained such that hazards caused by electrostatic discharge are excluded.
- Limit switches with the following modules, to be supplied by a Class 2 or Limited Energy Source in accordance with CSA 61010-1-12: FEL42, FEL48, FEL62, FEL64DC, and FEL68.

© 2019 CSA Group. All rights reserved.

Certificate: 80140625 **Master Contract:** 221913
Project: 80228740 **Date Issued:** January 21, 2025

CLASS 2258 04 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe Entity - For Hazardous Locations
CLASS 2258 84 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe Entity - For Hazardous Locations–Certified to U.S. Standards

Class I, Division 1, Groups A, B, C and D T6…T1
Ex ia IIC T6…T1 Ga
Class I, Zone 0 AEx ia IIC T6…T1 Ga

Product	Liquiphant, LVL-M3- h j kkk i - d e f g b c - aa XX .XXXX where aa (approval) = CH b (output) = E, W, N c (display; operation) = A d (housing; material) = A e (electrical conn.) = B, F, I f (application) = A g (surface finish) = A h (probe version) = A, C, B i (probe length; mat.) = 1 alphanumeric characters (not relevant for safety) j (process conn., sealing) = 1 alphanumeric characters (not relevant for safety) kkk (process conn., size) = 3 alphanumeric characters (not relevant for safety) + (additional options; any number of each of the following options may be chosen) XX (services) = 2 alphanumeric characters (not relevant for safety) XX (test; Certificate) = 2 alphanumeric characters (not relevant for safety) XX (additional approvals) = 2 alphanumeric characters (not relevant for safety) XX (accessories mounted) = 2 alphanumeric characters (not relevant for safety) XX (accessories enclosed) = WP; or 2 alphanumeric characters (not relevant for safety) XX (marking) = 2 alphanumeric characters (not relevant for safety) Note: Some option codes may be restricted for certain model types.
Electrical Rating	Dependent on Output option, b: I.S. connection parameters are defined in the below table N(FEL48): 8.2Vdc, NAMUR
Enclosure Rating	Type 4X/6P, IP66/68
Temp. code and ambient/process temperature	T6…T3 with standard Ta of -40°C to + 70°C; (0°C to + 70°C, where option d = A) and process temperature -40°C to +150°C; refer to installation drawing for specific T-code and limitations of temperature ranges
MWP/Process Seal	580 psi (40 bar) Single Seal
Installation Drawing	Intrinsically safe when installed per DOCT-8480

I.S. Connections Parameters for LVL-M3:

Output code “b”	N (FEL48)
Input X100 (Power)	Ui = 16 V Ii = 52 mA Pi =170 mW Ci = 30 nF Li = N/A µH

© 2019 CSA Group. All rights reserved.

Certificate: 80140625 **Master Contract:** 221913
Project: 80228740 **Date Issued:** January 21, 2025

Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; Class III T6…T1
Ex ia IIC T6…T1 Ga
Class I, Zone 0, AEx ia IIC T6…T1 Ga

<table>
<tr><td>Product</td><td>Liquiphant, series LVL-M4- h j kkk i – d e f g b c -aa XX .XXXX

where
aa (approval) = CI
b (output) = A, E, B, N, M
c (display; operation) = A, B
d (housing; material) = A, G, D
e (electrical conn.) = B, C, F, H and I
f (application) = A, B, C
g (surface finish) = A, Y (LVL-M4)
h (probe version) = A, C, B
i (probe length; mat.) = 1 alphanumeric characters (not relevant for safety)
j (process conn., sealing) = 1 alphanumeric characters (not relevant for safety)
kkk (process conn., size) = 3 alphanumeric characters (not relevant for safety)
+ (additional options; any number of each of the following options may be chosen)
XX (operating lang.) = 2 alphanumeric characters (not relevant for safety)
XX (Applic. Package) = 2 alphanumeric characters (not relevant for safety)
XX (test; Certificate) = U1, U2; or 2 alphanumeric characters (not relevant for safety)
XX (additional approvals) = 2 alphanumeric characters (not relevant for safety)
XX (sensor design) = TD, DF, M9
XX (accessories mounted) = BL, VB, O9
XX (accessories enclosed) = WS, WP, ST, XX
XX (firmware vers.) = 2 alphanumeric characters (not relevant for safety)
XX (marking) = 2 alphanumeric characters (not relevant for safety)

Note: Some option codes may be restricted for certain model types.</td></tr>
<tr><td>Electrical Rating</td><td>Dependent on option b (output): I.S. connection parameters are defined in the below table
M (FEL68): 8.2Vdc, NAMUR</td></tr>
<tr><td>Enclosure Rating</td><td>Type 4X/6P, IP66/68</td></tr>
<tr><td>Temp. code and ambient/process temperature</td><td>
<table>
<tr><td>Temperature Code and Ambient Temperature Range</td><td colspan="2">Extensions/Limitations based on options:</td></tr>
<tr><td rowspan="3">T6…T3
-40°C to + 70°C</td><td>xx= U1</td><td>min. temp = -50ºC</td></tr>
<tr><td>qq= BL, VB</td><td>max. temp = +65 ºC</td></tr>
<tr><td>qq= VB</td><td>T-code = T4…T3</td></tr>
<tr><td colspan="3">Process temperature -50°C to +150°C;
refer to installation drawing for specific T-code and additional derating of temperature ranges.</td></tr>
</table>
</td></tr>
<tr><td>MWP/Process seal</td><td>Dependent on option f (application):
A: 928 psi (64 bar)
B: 1450 psi (100 bar)
C: 362 psi (25 bar)
Single Seal</td></tr>
<tr><td>Installation Drawing</td><td>Intrinsically safe when installed per DOCT-8486</td></tr>
</table>

© 2019 CSA Group. All rights reserved.

I.S. Connections Parameters for LVL-M4…

Output code "b"	**B (FEL68)**
Input X100 (Power)	Ui = 16 V Ii = 52 mA Pi =170 mW Ci = 30 nF Li = N/A µH

Conditions of Acceptability:

- The Liquid Level Switches Liquiphant shall be installed and maintained such that hazards caused by electrostatic discharge are excluded.
- For Liquid Level Switches Liquiphant with an aluminium enclosure, when used as EPL Ga equipment, shall be installed in such a way that, even in the event of rare incidents, ignition sources due to impact and friction between the enclosure and iron or steel are excluded.

© 2019 CSA Group. All rights reserved.

Certificate: 80140625 **Master Contract:** 221913
Project: 80228740 **Date Issued:** January 21, 2025

CLASS 2252 06 - PROCESS CONTROL EQUIPMENT
CLASS 2252 86 - PROCESS CONTROL EQUIPMENT (Certified to U.S. Standards)

Product	Liquiphant, LVL-M3- h j kkk i - d e f g b c - aa XX .XXXX where aa (approval) = CG b (output) = E, W, N c (display; operation) = A d (housing; material) = A e (electrical conn.) = B, F, I f (application) = A g (surface finish) = A h (probe version) = A, C, B i (probe length; mat.) = 1 alphanumeric characters (not relevant for safety) j (process conn., sealing) = 1 alphanumeric characters (not relevant for safety) kkk (process conn., size) = 3 alphanumeric characters (not relevant for safety) + (additional options; any number of each of the following options may be chosen) XX (services) = 2 alphanumeric characters (not relevant for safety) XX (test; Certificate) = 2 alphanumeric characters (not relevant for safety) XX (additional approvals) = 2 alphanumeric characters (not relevant for safety) XX (accessories mounted) = 2 alphanumeric characters (not relevant for safety) XX (accessories enclosed) = WP; or 2 alphanumeric characters (not relevant for safety) XX (marking) = 2 alphanumeric characters (not relevant for safety) Note: Some option codes may be restricted for certain model types.
Electrical Rating	Dependent on Output option, b: E (FEL42): 10…55Vdc, 350 mA; W (FEL44): 19…253 Vac, 25VA, 50/60Hz or 19…55Vdc, 1.3W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A N (FEL48): 8.2Vdc, NAMUR
Enclosure Rating	Type 4X/6P, IP66/68
Ambient/process temperature	Standard Ta of -40°C to + 70°C. ; (0°C to + 70°C, where option d = A) Process temperature -40°C to +150°C;
MWP	580 psi (40 bar)

Product	Liquiphant, series LVL-M4- h k lll i – d e f g b c -aa XX .XXXX where aa (approval) = CG b (output) = A, E, B, N, M c (display; operation) = A, B d (housing; material) = P, A, G, D e (electrical conn.) = A, B, C, F, G, H, I, M f (application) = A, B, g (surface finish) = A, Y **(**LVL-M4**)** h (probe version) = A, C, B i (probe length; mat.) = 1 alphanumeric characters (not relevant for safety) k (process conn.) = 1 alphanumeric characters (not relevant for safety) lll (process conn. size) = 3 alphanumeric characters (not relevant for safety) xx (additional options; any number of each of the following options may be chosen) xx (operating lang.) = 2 alphanumeric characters (not relevant for safety)

© 2019 CSA Group. All rights reserved.

	xx (Applic. Package) = 2 alphanumeric characters (not relevant for safety) xx (test; Certificate) = U1, U2; or 2 alphanumeric characters (not relevant for safety) xx (additional approvals) = 2 alphanumeric characters (not relevant for safety) xx (sensor design) = TD, DF, M9 xx (accessories mounted) = BL, VB, O9 xx (accessories enclosed) = WS, WP, ST, XX xx (firmware vers.) = 2 alphanumeric characters (not relevant for safety) xx (marking) = 2 alphanumeric characters (not relevant for safety) Note: Some option codes may be restricted for certain model types.
Electrical Rating	Dependent on option b (output): A (FEL61): 19…253 Vac, 2VA, 50/60Hz E (FEL62): 10…55Vdc, 350 mA B (FEL64DC): 9…20Vdc, 1W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A N (FEL64): 19…253 Vac, 25VA, 50/60Hz or 19…55Vdc, 1.3W; contacts rated 253Vac/2A, 500VA (pf=1) / 250VA (pf = 0.7), or 125Vdc/0.2A M (FEL68): 8.2Vdc, NAMUR
Enclosure Rating	Type 4X/6P, IP66/68
Ambient/process temperature	Standard Ta of -40°C to + 70°C; -50°C to + 70°C, where option; -60°C to + 70°C, where option; 0°C to + 70°C, where option d = P Process temperature -50°C to +150°C.
MWP	Dependent on option f (application): A: 928 psi (64 bar) B: 1450 psi (100 bar) C: 362 psi (25 bar)

Conditions of Acceptability:

1. Limit switches with the following modules, to be supplied by a Class 2 or Limited Energy Source in accordance with CSA 61010-1-12: FEL48, FEL64DC and FEL68.
2. Rated: Pollution Degree 2, Overvoltage Category I (limited energy modules, FEL42, FEL48, FEL62, FEL64DC and FEL68) or Overvoltage Category II
3. Environmental Conditions: 3000 m max
4. Ambient temperature: -40°C for LVL-M3 and LVL-M4 (optional for LVL-M4, and -50°C/ -52°C/-60°C, only when using metallic enclosure and voltage is <35Vdc) to + 70°C max. Minimum ambient temperature for models with polymeric enclosure (option d = P) is limited to 0 °C.

   For devices with a temperature spacer, the following ambient temperatures apply across the entire process temperature range: A: +70 °C; B: +60 °C.

   Low-temperature electronic inserts are marked LT (-50°C/-52°C/-60°C).
   - Bluetooth module (non-Ex): –40 to +70 °C
   - Bluetooth module (Ex ia): –40 to +65 °C
   - LED module: –40 to +60 °C
5. Complete device may have optional LED module in addition to FEL62, FEL64, or FEL64DC insert. LED module is supplied at the same voltage as the insert; 6VA max for ac, 0.7W max for dc.

© 2019 CSA Group. All rights reserved.

6. Complete device may have optional Bluetooth module in addition to FEL61, FEL62, FEL64, FEL64DC, or FEL68 inserts. Bluetooth module is supplied either by battery (only FEL68) or at 30Vdc max., by the insert; 0.1A max.

APPLICABLE REQUIREMENTS

C22.2 No. 25-17	Enclosures for use in Class II, Division 1, Groups E, F, and G hazardous locations
C22.2 No. 30-M1986 (r2016)	Explosion-proof enclosures for use in Class I hazardous locations
CSA C22.2 No. 94.2-15	Enclosures for Electrical Equipment, Environmental Considerations
CAN/CSA-C22.2 No. 61010-1-12	Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements
CAN/CSA-C22.2 No. 60079-0:19	Explosive atmospheres – Part 0: Equipment – General requirements
CAN/CSA-C22.2 No. 60079-1:16	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures “d”
CAN/CSA-C22.2 No. 60079-11:14	Explosive atmospheres – Part 11: Equipment protection by intrinsic safety “i”
CAN/CSA-C22.2 No. 60079-26:16	Explosive atmospheres – Part 26: Equipment with Equipment Protection Level (EPL) Ga
CAN/CSA C22.2 No. 213-17	Non-incendive Electrical Equipment for Use in Class I and II, Division 2, and Class III Hazardous (Classified) Locations
UL 61010-1-Third Edition	Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements
FM3600-2022	Approval Standard for Electrical Equipment for Use in Hazardous (Classified) Locations - General Requirements
FM3610-2021	Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II and III, Division 1, Hazardous (Classified) Locations
FM3615-2018	Approval Standard for Explosionproof Electrical Equipment General Requirements
FM3616-2022	Approval Standard for Dust-Ignitionproof Electrical Equipment General Requirements
UL 50E-15, Second Edition	Enclosures for Electrical Equipment, Environmental Considerations
UL 60079-0-2019, Seventh Edition	Explosive atmospheres – Part 0: Equipment – General requirements
UL 60079-1-2015, Seventh Edition	Explosive Atmospheres – Part 1: Equipment Protection by Flameproof Enclosures “d”
UL 60079-11-2014, Sixth Edition	Explosive Atmospheres – Part 11: Equipment Protection by Intrinsic Safety “i”
UL-60079-26: Third Edition	Explosive atmospheres – Part 26: Equipment with Equipment Protection Level (EPL) Ga
UL 121201-2017, Ninth Edition	Non-incendive Electrical Equipment for Use in Class I and II, Division 2, and Class III Hazardous (Classified) Locations
ANSI/UL 122701- 2017, Third Edition	Requirements for Process Sealing Between Electrical Systems and Flammable or Combustible Process Fluids

© 2019 CSA Group. All rights reserved.

Certificate: 80140625 **Master Contract:** 221913

Project: 80228740 **Date Issued:** January 21, 2025

Notes:

Products certified under Class C225803, C225883, 2258 04, 2258 84, 2252 06, 2252 86 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca

© 2019 CSA Group. All rights reserved.