Certificate of Compliance

Certificate Number(s):

UL-US-2565859-1
UL-US-2565854-1

Report Reference:

E106378-20250522

Issue Date:

2026-04-13

Issued to:

Pepperl+Fuchs SE
Lilienthalstrasse 200, Mannheim, 68307, DE

This certificate confirms that representative samples of:
QVAJ - Process Control Equipment for Use in Zone Classified Hazardous Locations
QUZW - Process Control Equipment for Use in Hazardous Locations

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 60079-0, Edition 7, Issue Date 2019-03-26, Revision Date 2024-07-19
UL 61010-1, 3rd Ed., Issue Date: 2012-05-11, Revision Date: 2023-06-06
UL 60079-7:2017 (R2025), Edition 5, Issue Date 2017-02-24, Revision Date 2025-09-10
UL 60079-11:2026, Edition 7, Issue Date 2026-01-30
UL 913, Edition 8, Issue Date 2013-12-06, Revision Date 2022-05-10
UL 121201, Edition 9, Issue Date 2017-09-15, Revision Date 2025-07-30

Additional Information:
See UL Product iQ® at https://iq.ulprospector.com for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2026 UL LLC. All rights reserved.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-2565859-1, UL-US-2565854-1
Report reference: E106378-20250522
Issue Date: 2026-04-13

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Class I, Division 2, Group A, B, C and D provides Intrinsically safe circuit extensions for use in Class I, Division 1, Group A, B, C and D, Class II, Division 1, Group E, F and G, Class III, when installed in accordance with Control Drawing No(s). 116-0504A, Voltage Repeater

KCD2-VR4, **Model(s):** KCD2-VR4-Ex1.2, KCD2-VR4-Ex1.B, KCD2-VR4-Ex1.B2, KCD2-VR4-Ex1 *may be followed by .SP*

Zone 2, Class I, Zone 2, AEx ec [ia Ga] IIC T4 Gc, [AEx ia Da] IIIC Provides intrinsically safe circuit extensions for use in Zone 0, IIC, Zone 20, IIIC, when installed in accordance with Control Drawing No(s) 116-0504A, Voltage Repeater

KCD2-VR4, **Model(s):** KCD2-VR4-Ex1.2, KCD2-VR4-Ex1.B, KCD2-VR4-Ex1.B2, KCD2-VR4-Ex1 *may be followed by .SP*

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2026 UL LLC. All rights reserved.