Certificate of Compliance

Certificate Number(s):

UL-CA-L106378-47761-22100102-2

Report Reference:

E106378-20100122

Issue Date:

2025-10-22

Issued to:

Pepperl+Fuchs SE
Lilienthalstrasse 200, Mannheim, 68307, DE

This certificate confirms that representative samples of:

QUZW7 - Process Control Equipment for Use in Hazardous Locations Certified for Canada

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

See Addendum Page for Standards.

Additional Information:
See UL Product iQ® at https://iq.ulprospector.com for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2025 UL LLC. All rights reserved.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-CA-L106378-47761-22100102-2
Report reference: E106378-20100122
Issue Date: 2025-10-22

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Associated apparatus, barriers

Model(s): KFD0-SD2-EX1.1180 *provides intrinsically safe circuits for use in Class I, Groups C and D, Class II, Groups E, F and G, Class III hazardous locations when installed in accordance with manufacturer"s control drawing No. 116-0316.*

Model(s): KFD0-SD2-EX1.1045, KFD0-SD2-EX2.1045, KFD0-SD2-EX1.1245, KFD0-SD2-EX2.1245, KFD0-SD2-EX1.1065, KFD0-SD2-EX2.1065, KFD0-SD2-EX1.10100 *providing intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, Class III hazardous locations when installed in accordance with manufacturer"s control drawing no. 116-0316.*

Standards for Safety:

CAN/CSA C22.2 No. 157-92, Rev. 2003-06, Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations.

CAN/CSA C22.2 No. 213-M1987, 1st Ed., Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations.

CAN/CSA C22.2 No. 61010-1, 2nd Edition, Rev. 2005-07-22, Safety Requirements For Electrical Equipment For Measurement, Control, And Laboratory Use, Part 1: General Requirements.

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2025 UL LLC. All rights reserved.