

MANUFACTURER'S DECLARATION OF CONFORMITY

We:

Pepperl+Fuchs SE
Lilienthalstraße 200
68307 Mannheim
Germany

declare under our own responsibility that the IO-Link Device product(s):

PXV100Q-F213-IO*

See details in Annex – Conform products

to which this declaration refers conform to:

- ☒ IO-Link Interface and System Specification, V1.1.5, Oct 2025
(NOTE 1)
- ☒ IO Device Description, V1.1.5, Oct 2025
- ☒ Additional conformance to Device Profiles
(If checked refer to Part A on page 2)
- ☐ Additional conformance to System Extensions
(If checked refer to Part B on page 2)
- ☒ Conformance exceptions
(If checked refer to Part C on page 2)

The conformity tests are documented in the test report(s):

PRDE-DC25

Issued at Mannheim, 2026-07-10

Authorized signatory



Name: i.V. Hilmar Hofmann
Title: *Head of Innovation Unit
Industrial Vision Sensors*



i.V. Salina Popp
*Technical Product Manager
Industrial Vision Sensors*

Reproduction and all distribution without written authorization prohibited

NOTE 1 Relevant Test specification is V1.1.5, Oct 2025

MD-Version: V1.1.5 / 2026-02

Part A - Additional conformance to Device Profiles

	Specification
☒	IO-Link Common Profile Specification, V1.2.1, Oct. 2025
☒	IO-Link Profile BLOB Transfer & Firmware Update Specification, V1.2.1, Oct. 2025
☐	IO-Link Profile Smart Sensors 2 nd Edition Specification, V1.2.1, Oct. 2025

Part B - Additional conformance to System Extensions

	Specification
☐	IO-Link Safety System Extensions, V1.1.5, Oct. 2025

Part C - Conformance exceptions

We herewith declare the following deviations to the related specifications	Reason
Power-on wake-up readiness delay according to Exception 24-01	This Device may delay the communication up to 3 seconds after power-on. This may result in failure reactions of the system following power-on.

Annex – Conform products

Product name	Device ID
PXV100Q-F213-IO-0.3M-V15	6291969 (0x600201)