



1 EU-TYPE EXAMINATION CERTIFICATE

2 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

3 Certificate Number: Sira 07ATEX1135 Issue: 4

4 Equipment: F150 Range of Junction Boxes, Control panels, Instrument control

panels and Distribution boards

5 Applicant: **Pepperl+Fuchs GmbH** (orporating the Govan

brand)

6 Address: Lilienthalsraße 200 These products ma

68307 Mannheim

Germany

These products may only be manufactured at any Pepperl+Fuchs, Facility that has been audited for the manufacture of the type of protection defined on this certificate; in addition, the site must also be listed on the Quality Assessment Notification PTB 16 ATEX Q001, PTB 97 ATEX Q008 and PTB 97ATEX Q020 or their subsequent issues.

- 7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- 8 CSA Group Netherlands B.V., notified body number 2813 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN 60079-0:2006

EN 60079-1:2004

EN 60529:1992 (. A1 & A2)

- If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to Specific Conditions of Use identified in the schedule to this certificate.
- 11 This EU-Type Examination Certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.
- 12 The marking of the equipment shall include the following:



II 2 G

F150 Enclosures

Ex d IIB T6 IP66 -20°C \leq Ta \leq +40°C,+55°C or +60°C

FH150 Enclosures

Ex d IIB +Hydrogen T6 IP66

 $-20^{\circ}\text{C} \le \text{Ta} \le +40^{\circ}\text{C}, +55^{\circ}\text{C} \text{ or } +60^{\circ}\text{C}$

Project Number 1027

SVIC

Signed: <

Title: Director of Operations

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V. Utrechseweg 310, 6812 AR, Arnhem, Netherlands

Page 1 of 4

DQD 544.09 Rev 2018-04-20





SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 07ATEX1135 Issue 4

13 **DESCRIPTION OF EQUIPMENT**

The F150 and FH150 Range are rectangular enclosures fitted with a bolted cover forming a flameproof flange joint. The main body and cover are constructed from cast aluminium alloy, stainless steel or cast iron and there is an option of a toughened glass window to be fitted within the cover. The M10 cover fasteners have a minimum yield stress of 1115 N/mm².

The enclosures are fitted with O-rings for the prevention of water and dust ingress and have been independently tested according to the requirements of IEC 60529 to meet IP 66.

Each enclosure is marked with the total power dissipation and components may be fitted not exceeding this. The maximum power dissipation values are as follows:

Ambient	Maximum Power	Maximum Power Dissipation	Temperature
Temperature range	Dissipation (W)	(W) when fitted with windows	Classification
-20°C to +40°C	160	140	T6
-20°C to +55°C	102	89	T6
-20°C to +60°C	82	71	T6

The F150 and FH150 range may be supplied in any of the following configurations:

Type Reference	Description
F150-JB	Junction box having a plain cover and containing feed through type terminals.
F150-CP	Control panel having a cover fitted with up to 24 Govan switch or indicator light
	modules and containing relays, timers, contactors and motor starters.
F150-A2	Instrument control panel having an A2 window and containing instruments or
	process control equipment.
F150-A5	Instrument enclosure having an A5 window and containing instruments or process
	control equipment.
F150-CB	Distribution board having a cover fitted with up to 10 switch operators and
	containing circuit breaker, load-break or isolating switches.
FH150-JB	Junction box having a plain cover and containing feed through type terminals.
FH150-CP	Control panel having a cover fitted with up to 24 Govan switch or indicator light
	modules and containing relays, timers, contactors and motor starters.
FH150-A4	Instrument control panel having an A4 window and containing instruments or
	process control equipment.
FH150-CB	Distribution board having a cover fitted with up to 10 switch operators and
	containing circuit breaker, load-break or isolating switches.

The enclosures may be supplied with Govan MN-7 (F150) or MNH-7 (FH150) blanking plug modules to close unused apertures. The following Govan components may be fitted:

- 1. MN-1, 2, 3, 4, 5 & 8 Push button module for Group IIB applications
- 2. MN-6 Push button module (pad lockable) for Group IIB applications
- 3. MN-7 Plug module for Group IIB applications
- 4. MN-9 Indicator light module (andescent type) for Group IIB applications
- 5. MN-11 Indicator light module (LED transformer type) for Group IIB applications
- 6. SM-10 10 Amp to 20 Amp switch module for Group IIB applications
- 7. SM-20 to 63 Amp Switch module for Group IIB applications
- 8. MNH-1, 2, 3, 4, 5 & 8 Push button module for Group IIB +Hydrogen applications
- 9. MN-7 Plug module for Group IIB +Hydrogen applications

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V. Utrechseweg 310,

6812 AR, Arnhem Netherlands

DQD 544.09 Rev 2018-04-20 Page 2 of 4





SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 07ATEX1135 Issue 4

- 10. MN-9 Indicator light module (andescent type) for Group IIB +Hydrogen applications
- 11. MN-11 Indicator light module (LED transformer type) for Group IIB +Hydrogen applications
- 12. SM-10 10 Amp to 20 Amp switch module for Group IIB +Hydrogen applications

Variation 1 - This variation introduced the following changes:

- i. To permit the removal of the Special Condition of Safe Use, hence the Certificate number has been amended to remove the 'X' suffix.
- ii. To allow the Description of Equipment to be updated.
- iii. To permit an rease in ambient temperature to +55°C or +60°C hence, the maximum power dissipation values are now detailed in the Description of Equipment, the Marking was amended accordingly.

Variation 2 - This variation introduced the following change:

i. The Applicants name and address was changed from Govan Industries Pty Ltd, 131-149 Link Drive, Campbellfield, Victoria, 3061, Australia to that currently shown in Sections 5 and 6 above.

Variation 3 - This variation introduced the following changes:

- i. The Notified Body number, responsible for quality, was changed to 0102.
- ii. The alternative manufacturing locations were removed from the description as they are now covered by the statement in section 6 of the certificate.

14 **DESCRIPTIVE DOCUMENTS**

14.1 Drawings

Refer to Certificate Annexe.

14.2 Associated Sira Reports and Certificate History

Issue	Date	Report number	Comment
0	25 September 2007	R51A16570E	The release of the prime certificate.
1	5 September 2012	R27424A/00	The introduction of Variation 1.
2	10 July 2013	R30253A/00	The introduction of Variation 2.
3	01 February 2017	R70089891A	 This Issue covers the following changes: EC Type-Examination Certificate in accordance with 94/9/EC updated to EU Type-Examination Certificate in accordance with Directive 2014/34/EU. (In accordance with Article 41 of Directive 2014/34/EU, EC Type-Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Variations to such EC Type-Examination Certificates may continue to bear the original certificate number issued prior to 20 April 2016.) The introduction of Variation 3.
4	15th October 2019	1027	Transfer of certificate Sira 07ATEX1135 from Sira Certification Service to CSA Group Netherlands B.V

This certificate and its schedules may only be reproduced in its entirety and without change **CSA Group Netherlands B.V.** Utrechseweg 310, 6812 AR, Arnhem Netherlands

DQD 544.09 Rev 2018-04-20 Page 3 of 4





SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 07ATEX1135 Issue 4

15 **SPECIFIC CONDITIONS OF USE** (denoted by X after the certificate number)
None

16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

DQD 544.09 Rev 2018-04-20 Page 4 of 4

Certificate Annexe



Certificate Number: Sira 07ATEX1135

Equipment: F150 Range of Junction Boxes, Control panels, Instrument control panels

and Distribution boards

Applicant: Pepperl+Fuchs GmbH (orporating the Govan brand)

Issue 0

Drawing no:	Sheets	Rev.	Date	Description
C2032	1 of 1	6	03 Sep 07	Ex d IIB T6 IP66 Junction Box F150-JB
C2033	1 of 1	3	15 Dec 06	Ex d IIB T6 IP65 Control Panel F150-CP
C2034	1 of 1	3	15 Dec 06	Ex d IIB T6 IP65 Instrument Control Panel F150-A2
C2035	1 of 1	4	15 Dec 06	Ex d IIB T6 IP65 Distribution Board F150-CB
C2036	1 of 1	6	15 Dec 06	Ex d IIB T6 IP66 Instrument Enclosure
C2385	1 to 6	1	27 Nov 06	Equipment Listing for Govan FH150 & F150
C5119	1 of 1	6	03 Sep 07	Ex d IIB+Hydrogen T6 IP66 Junction Box FH150-JB
C5120	1 of 1	3	15 Dec 06	Ex d IIB+Hydrogen T6 IP65 Control Panel FH150-CP
C5121	1 to 2	2	15 Dec 06	Ex d IIB+Hydrogen T6 IP65 Instrument Panel FH150-A4
C5122	1 of 4	3	15 Dec 06	Ex d IIB+Hydrogen T6 IP66 Enclosures
C5122	2 of 4	3	15 Dec 06	Ex d IIB+Hydrogen T6 IP66 Enclosures
C5122	3 of 4	5	15 Dec 06	Ex d IIB+Hydrogen T6 IP66 Enclosures
C5122	4 to 4	4	15 Dec 06	Ex d IIB+Hydrogen T6 IP66 Enclosures
C5123	1 of 1	2	15 Dec 06	Ex d IIB+Hydrogen T6 IP66 Distribution Board FH150-CB
C0774	1 of 1	9	15 Dec 06	Govan Module range for Ex d IIB T6 IP66 Enclosures

Issue 1

Drawing	Sheets	Rev.	Date (Sira Stamp)	Title
C2032	1 of 1	9	31 Aug 12	Ex d IIB T6 IP66 Junction Box F150-JB
C5119	1 of 1	9	31 Aug 12	Ex d IIB+Hydrogen T6 IP66 Junction Box FH150-JB

Issue 2

Drawing	Sheets	Rev.	Date (Sira Stamp)	Description
GC 0651	1 to 2	0	07 Mar 13	Compliance Name Plate detail for company name change

Issue 3 No new drawings were introduced

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V. Utrechseweg 310, 6812 AR, Arnhem, Netherlands

DQD 544.09 Rev 2018-04-20 Page 1 of 1