

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170411-E179102  
**Report Reference** E179102-20120716  
**Issue Date** 2017-APRIL-11

**Issued to:** Pepperl+Fuchs Inc  
1600 ENTERPRISE PKWY  
TWINSBURG OH 44087-2202

**This is to certify that  
representative samples of**

SWITCHES, INDUSTRIAL CONTROL; ENERGY AND  
INDUSTRIAL SYSTEMS CERTIFIED FOR FUNCTIONAL  
SAFETY

See Addendum

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** ANSI/UL 508  
EN ISO/ISO 13849-1 (2006)

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170411-E179102  
**Report Reference** E179102-20120716  
**Issue Date** 2017-APRIL-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model No.	Safety Function	Safety Rating
Safety Amplifiers		
KE5A5-6H/2R-S (a)		
	Safety Amplifier	PL d
KE5A5-6H/2R-S (b)		
	Safety Amplifier	PL d
KE5D2-6H/2R-S (a)		
	Safety Amplifier	PL d
KE5D2-6H/2R-S (b)		
	Safety Amplifier	PL d

(a) - With daily maintenance.

(b) - Without daily maintenance.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

