

CERTIFICATE OF COMPLIANCE

Certificate Number 20140407-E106378
Report Reference E106378-20110525
Issue Date 2014-APRIL-07

Issued to: Pepperl+Fuchs Inc
1600 ENTERPRISE PKWY
TWINSBURG OH 44087-2202

**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS; PROCESS CONTROL
EQUIPMENT FOR USE IN ZONE CLASSIFIED
HAZARDOUS LOCATIONS


See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20140407-E106378
Report Reference E106378-20110525
Issue Date 2014-APRIL-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL - Class I, Division 2, Groups A, B, C and D Hazardous Locations

USL - Class I, Zone 2, AEx nA [ic] IIC T6 Gc; AEx nA [ic IIIB] IIC T6 Gc

CNL - Class I, Zone 2, Ex nA [ic] IIC T6 Gc X; Ex nA [ic IIIB] IIC T6 Gc X

Associated Non-incendive Field Wiring Apparatus (ANIFWA), Model SK-PC-D2-UU1-10-HS, Non-incendive Barriers provide nonincendive field wiring for Class I, Division 2, Groups A, B, C and D, Class II, Division 2, Groups F and G and Class III, Division 2 Hazardous Locations and intrinsic safety wiring for Class I, Zone 2, Group IIC Hazardous Locations when installed per Control Drawing 116-0337.

USL, CNL - Class I, Division 2, Groups C and D Hazardous Locations

Associated Non-incendive Field Wiring Apparatus (ANIFWA), Models SK-PC-D2-UN2-10-HS and SK-PC-D2-RN2-10-HS Non-incendive Barriers provide nonincendive field wiring for Class I, Division 2, Groups C and D, Class II, Division 2, Groups F and G and Class III, Division 2 Hazardous Locations when installed per Control Drawing 116-0337.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20140407-E106378
Report Reference E106378-20110525
Issue Date 2014-APRIL-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

ANSI/ISA 12.12.01-2013 - Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Division

Standard No. CAN/CSA C22.2 No. 213-M1987 - Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

UL 61010-1 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

CAN/CSA C22.2 No. 61010-1 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

UL 60079-0 - Explosive atmospheres – Part 0: Equipment – General Requirements

UL 60079-11 - Explosive atmospheres – Part 11: Equipment Protection by Intrinsic Safety

UL 60079-15 - Electrical Apparatus for Explosive Gas Atmospheres – Part 15: Construction, Test and Marking of Type of Protection “n” Electrical Apparatus

CAN/CSA C22.2 No. 60079-0:11 - Explosive atmospheres – Part 0: Equipment – General Requirements

CAN/CSA-C22.2 No. 60079-11: 11 - Explosive atmospheres – Part 11: Equipment Protection by Intrinsic Safety

CAN/CSA-C22.2 No. 60079-15:12 - Electrical Apparatus for Explosive Gas Atmospheres – Part 15: Construction, test and marking of type of protection “n” electrical apparatus



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

