

CERTIFICATE OF COMPLIANCE

Certificate Number E184741
Report Reference E184741-2008-02-26
Date 2022-August-05

Issued to: Pepperl+Fuchs SE
Lilienthalstrasse 200
Mannheim 68307 DE

**This is to certify that
representative samples of**

PURGING AND PRESSURIZING CONTROLS AND
ACCESSORIES FOR USE IN HAZARDOUS LOCATIONS
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See addendum page for Standards.

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E184741
Report Reference E184741-2008-02-26
Date 2022-August-05

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Models:

USC, CNC – Class I, Division 1, Groups A, B, C and D Hazardous Locations

1. Purge and Pressurization Control System Component Kit, Model 6000, followed by EXKIT followed by AC or DC, followed by XX, where XX can be any 2 alpha-numeric combination, may be followed by “blank” or GO. Device provides intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; Class III Hazardous Locations when installed per Control Drawing No. 116-B027 Issue A.

a. When provided with Model 6000-TEMP-01 Temperature Hub, intrinsically safe for use in Class I, Groups A, B, C, D and provides intrinsically safe connections for use in Class I, Groups A, B, C, D; Class II, Groups E, F, G; and Class III when installed per Control Drawing No. 116-B027 Issue A.

b. When provided with the optional I.S. Termination Board DIN mounted, Model 6000-ISB-XX, intrinsically safe connections for use in Class I, Groups A, B, C, D; Class II, Groups E, F, G; and Class III Class I, Div. 1, Groups A, B, C, D when installed per 116-B027 Issue A.

c. When provided with User Interface 6000-UIC-xx, may be followed by additional numbers or letters, intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.

d. Provided with Model EPV-6000-xx-xx Relief Vent, may be followed by additional numbers or letters, intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.

e. May be provided with up to three Model 6000-TSEN-01 Temperature Sensors intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.

f. May be provided with Manifold 6000-MAN-DV-xx, may be followed by additional numbers or letters, intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.


USC, CNC – Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; Class III Hazardous Locations

2. Purge and Pressurization Control System, Model 6000, followed by NV or DV followed by S2, followed by UN or 4AN, followed by WH, CK or XX, where XX can be any 2 alpha-numeric combination, followed by AC or DC. Device provides intrinsically safe circuits for use in Class I, Groups A, B, C, and D; Class II, Division 1, Groups E, F and G; Class III Hazardous Locations when installed per Control Drawing No. 116-B027 Issue A.

a. When provided with Model 6000-TEMP-01 Temperature Hub in a certified Class II, Division 1, Groups E, F and G; Class III Hazardous Locations enclosure, intrinsically safe for use in Class I, Groups A, B, C, D; Class II, Groups E, F, G; and Class III and provides intrinsically safe connections for use in Class I, Groups A, B, C, D; Class II, Groups E, F, G; and Class III when installed per Control Drawing No. 116-B027 Issue A.

b. When provided with the optional I.S. Termination Board DIN mounted, Model 6000-ISB-XX, in a certified Class II, Division 1, Groups E, F and G; Class III Hazardous Locations enclosure, intrinsically safe Class I, Div. 1, Groups A, B, C, D; Class II, Groups E, F, G; and Class III when installed per 116-B027 Issue A.

c. When provided with User Interface 6000-UIC-xx, may be followed by additional numbers or letters, in a certified Class II, Division 1, Groups E, F and G; Class III Hazardous Locations enclosure



Bruce Mahrenholz, Director North American Certification Program

UL LLC



CERTIFICATE OF COMPLIANCE

Certificate Number E184741
Report Reference E184741-2008-02-26
Date 2022-August-05

intrinsically safe for use in Class I, Groups A, B, C and D; Class II, Groups E, F, G; and Class III when installed per Control Drawing No. 116-B027 Issue A.

d. Provided with Model EPV-6000-xx-xx Relief Vent, may be followed by additional numbers or letters, intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.

e. May be provided with up to three Model 6000-TSEN-01 Temperature Sensors intrinsically safe Class I, Groups A, B, C, D and Class II, Groups E, F, G; and Class III when installed per Control Drawing No. 116-B027 Issue A.

f. May be provided with Manifold 6000-MAN-DV-xx, may be followed by additional numbers or letters, intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.

3. Purge and Pressurization Control System Component Kit, Model 6000, followed by EXKIT followed by AC or DC, followed by XX, where XX can be any 2 alpha-numeric combination, may be followed

by GD. Device provides intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; Class III Hazardous Locations when installed per Control Drawing No. 116-B027 Issue A.

a. When provided with Model 6000-TEMP-01 Temperature Hub in a certified Class II, Division 1, Groups E, F and G; Class III Hazardous Locations enclosure, intrinsically safe for use in Class I, Groups A, B, C, D; Class II, Groups E, F, G; and Class III and provides intrinsically safe connections for use in Class I, Groups A, B, C, D; Class II, Groups E, F, G; and Class III when installed per Control Drawing No. 116-B027 Issue A.

b. When provided with the optional I.S. Termination Board DIN mounted, Model 6000-ISB-XX, in a certified Class II, Division 1, Groups E, F and G; Class III Hazardous Locations, intrinsically safe Class I, Div. 1, Groups A, B, C, D; Class II, Groups E, F, G; and Class III when installed per 116-B027 Issue A.

c. When provided with User Interface 6000-UIC-xx, may be followed by additional numbers or letters, in a certified Class II, Division 1, Groups E, F and G; Class III Hazardous Locations enclosure, intrinsically safe for use in Class I, Groups A, B, C and D; Class II, Groups E, F, G; and Class III when installed per Control Drawing No. 116-B027 Issue A.

d. Provided with Model EPV-6000-xx-xx Relief Vent, may be followed by additional numbers or letters, intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.


e. May be provided with up to three Model 6000-TSEN-01 Temperature Sensors intrinsically safe Class I, Groups A, B, C, D and Class II, Groups E, F, G; and Class III when installed per Control Drawing No. 116-B027 Issue A.

f. May be provided with Manifold 6000-MAN-DV-xx, may be followed by additional numbers or letters, intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.

4. Accessory Enclosure, Model 6000, followed by DPE followed by XX, where XX can be any 2 alpha-numeric combination, followed by XXXX, where XXXX can be any 4 alpha-numeric combination.

CNC – Ex db ib [jb pxb] IIC T4 Gb Hazardous Locations

1. Purge and Pressurization Control System Component Kit, Model 6000, followed by EXKIT followed by AC or DC, followed by XX, where XX can be any 2 alpha-numeric combination, may be followed by “blank” or GO. Device provides intrinsically safe circuits for use in Class I, Zone 1, Group



Bruce Mahrenholz, Director North American Certification Program

UL LLC



CERTIFICATE OF COMPLIANCE

Certificate Number E184741
Report Reference E184741-2008-02-26
Date 2022-August-05

IIC; Class II, Zone 21 Hazardous Locations when installed per Control Drawing No. 116-B027 Issue A.

a. When provided with Model 6000-TEMP-01 Temperature Hub in a certified Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC Hazardous Locations enclosure and up to three Model 6000-TSEN-01 Temperature Sensors intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.

b. When provided with the optional I.S. Termination Board DIN mounted, Model 6000-ISB-XX, in a certified Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC Hazardous Locations enclosure, intrinsically safe Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC when installed per 116-B027 Issue A.

c. When provided with User Interface 6000-UIC-xx, may be followed by additional numbers or letters, in a certified Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC Hazardous Locations enclosure intrinsically safe Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC when installed per Control Drawing No. 116-B027 Issue A.

d. Provided with Model EPV-6000-xx-xx Relief Vent, may be followed by additional numbers or letters, intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.

e. May be provided with Manifold 6000-MAN-DV-xx, may be followed by additional numbers or letters, intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.

CNC – Ex db [ib pxb] IIC T4 Gb; Ex ib tb [ib pxb] IIIC T60°C Db Hazardous Locations

2. Purge and Pressurization Control System, Model 6000, followed by NV or DV followed by S2, followed by UN or 4AN, followed by WH, CK or XX, where XX can be any 2 alpha-numeric combination, followed by AC or DC. Device provides intrinsically safe circuits for use in Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC Hazardous Locations when installed per Control Drawing No. 116-B027 Issue A.

a. When provided with Model 6000-TEMP-01 Temperature Hub in a certified Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC Hazardous Locations enclosure and up to three Model 6000-TSEN-01 Temperature Sensors intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.

b. When provided with the optional I.S. Termination Board DIN mounted, Model 6000-ISB-XX, in a certified Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC Hazardous Locations enclosure, intrinsically safe Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC when installed per 116-B027 Issue A.


c. When provided with User Interface 6000-UIC-xx, may be followed by additional numbers or letters, in a certified Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC Hazardous Locations enclosure intrinsically safe Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC when installed per Control Drawing No. 116-B027 Issue A.

d. Provided with Model EPV-6000-xx-xx Relief Vent, may be followed by additional numbers or letters, intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.

e. May be provided with Manifold 6000-MAN-DV-xx, may be followed by additional numbers or letters, intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.

CNC – Ex db [ib pxb] IIC T4 Gb; Ex tb [ib pxb] IIIC T80°C Db Hazardous Locations

3. Purge and Pressurization Control System Component Kit, Model 6000, followed by EXKIT followed by AC or DC, followed by XX, where XX can be any 2 alpha-numeric combination, may be followed by GO or GD. Device provides intrinsically safe circuits for use in Class I, Zone 1, Group IIC; Class II, Zone 21 Hazardous Locations when installed per Control Drawing No. 116-B027 Issue A



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number E184741
Report Reference E184741-2008-02-26
Date 2022-August-05

- a. When provided with Model 6000-TEMP-01 Temperature Hub in a certified Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC Hazardous Locations enclosure and up to three Model 6000-TSEN-01 Temperature Sensors intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.
- b. When provided with the optional I.S. Termination Board DIN mounted, Model 6000-ISB-XX, in a certified Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC Hazardous Locations enclosure, intrinsically safe Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC when installed per 116-B027 Issue A.
- c. When provided with User Interface 6000-UIC-xx, may be followed by additional numbers or letters, in a certified Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC Hazardous Locations enclosure intrinsically safe Class I, Zone 1, Group IIC; Class II, Zone 21 Group IIIC when installed per Control Drawing No. 116-B027 Issue A.
- d. Provided with Model EPV-6000-xx-xx Relief Vent, may be followed by additional numbers or letters, intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.
- e. May be provided with Manifold 6000-MAN-DV-xx, may be followed by additional numbers or letters, intrinsically safe when installed per Control Drawing No. 116-B027 Issue A.

CNC – Ex ib IIC T4 Gb; Ex ib IIIC T60°C Db Hazardous Locations

4. Accessory Enclosure, Model 6000, followed by DPE followed by XX, where XX can be any 2 alpha-numeric combination, followed by XXXX, where XXXX can be any 4 alpha-numeric combination.

Standards:

UL 508, INDUSTRIAL CONTROL EQUIPMENT,
CSA C22.2 NO. 14-18 INDUSTRIAL CONTROL EQUIPMENT,
UL 840 INSULATION COORDINATION INCLUDING CLEARANCES AND CREEPAGE DISTANCES FOR ELECTRICAL EQUIPMENT,
UL50 ENCLOSURES FOR ELECTRICAL EQUIPMENT, NON-ENVIRONMENTAL CONSIDERATIONS,
UL 50E ENCLOSURES FOR ELECTRICAL EQUIPMENT, ENVIRONMENTAL CONSIDERATIONS,
UL 913 INTRINSICALLY SAFE APPARATUS AND ASSOCIATED APPARATUS FOR USE IN CLASS I, II, III, DIVISION 1, HAZARDOUS (CLASSIFIED) LOCATIONS,
UL 60079-0, Explosive Atmospheres - Part 0: Equipment - General Requirements,
UL 60079-11, EXPLOSIVE ATMOSPHERES - PART 11: EQUIPMENT PROTECTION BY INTRINSIC SAFETY 'I',
CSA C22.2 NO. 157-92 INTRINSICALLY SAFE AND NON-INCENDIVE EQUIPMENT FOR USE IN HAZARDOUS LOCATIONS,
CSA C22.2 NO. 60079-11:14 EXPLOSIVE ATMOSPHERES — PART 11: EQUIPMENT PROTECTION BY INTRINSIC SAFETY "I",
CSA C22.2 NO. 60079-0:19 EXPLOSIVE ATMOSPHERES - PART 0: EQUIPMENT - GENERAL REQUIREMENTS,
CAN/CSA-C22.2 NO. 60079-1:16. EXPLOSIVE ATMOSPHERES — PART 1: EQUIPMENT PROTECTION BY FLAMEPROOF ENCLOSURES "D",
CAN/CSA-C22.2 NO. 60079-2:16., EXPLOSIVE ATMOSPHERES — PART 2: EQUIPMENT PROTECTION BY PRESSURIZED ENCLOSURE "P",



Bruce Mahrenholz, Director North American Certification Program


UL LLC



CERTIFICATE OF COMPLIANCE

Certificate Number E184741
Report Reference E184741-2008-02-26
Date 2022-August-05

CAN/CSA-C22.2 NO. 60079-31:15, EXPLOSIVE ATMOSPHERES — PART 31: EQUIPMENT DUST IGNITION PROTECTION BY ENCLOSURE "T",
NFPA 496, PURGED AND PRESSURIZED ENCLOSURES FOR ELECTRICAL EQUIPMENT,
UL 1203, EXPLOSION-PROOF AND DUST-IGNITION-PROOF ELECTRICAL EQUIPMENT FOR USE IN HAZARDOUS (CLASSIFIED) LOCATIONS,
CSA C22.2 NO. 25-17, ENCLOSURES FOR USE IN CLASS II GROUPS E, F, AND G HAZARDOUS LOCATIONS,
CAN/CSA C22.2 NO. 30-M1986, GENERAL INSTRUCTION NO. 2:1988-11, EXPLOSION-PROOF ENCLOSURES FOR USE IN CLASS I HAZARDOUS LOCATIONS,
CSA C22.2 No. 94.1 ENCLOSURES FOR ELECTRICAL EQUIPMENT, NON ENVIROMENTAL CONSIDERATIONS, and
CSA C22.2 No. 94.2 ENCLOSURES FOR ELECTRICAL EQUIPMENT, ENVIRONMENTAL CONSIDERATIONS



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

