

Certificate of Compliance

Certificate Number(s):

UL-US-2341539-1

Report Reference:

E184741-20080226

Issue Date:

2026-02-20

Issued to:

Pepperl+Fuchs SE
Lilienthalstrasse 200, Mannheim, 68307, DE

This certificate confirms that representative samples of:

RFPW - Purging and Pressurizing Controls and Accessories for Use in Hazardous Locations

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

NFPA 496, Edition 2024

UL 1203, Edition 6, Issue Date 2023-07-10, Revision Date 2023-10-05

UL 913, Edition 8, Issue Date 2013-12-06, Revision Date 2022-05-10

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-2341539-1
Report reference: E184741-20080226
Issue Date: 2026-02-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Class I, Division 1, Group A, B, C and D

Model(s): EPV-6000-xx-xx Relief Vent, may be followed by additional numbers or letters, intrinsically safe when installed

Model(s): 6000-TSEN-01 Temperature Sensors intrinsically safe when installed

Model(s): Model 6000 followed by EXKIT followed by AC, AH, DC or DH, followed by XX, where XX can be any 2 alpha-numeric combination, may be followed by "blank" or GO. Device provides intrinsically safe circuits

Model(s): 6000-UIC-xx may be followed by additional numbers or letters, intrinsically safe when installed

Class I, Division 1, Group A, B, C and D, Class II, Division 1, Group E, F and G, Class III, Division 1

Model(s): Model EPV-6000-xx-xx Relief Vent, may be followed by additional numbers or letters, intrinsically safe when installed

Model(s): Model 6000-TEMP-01 Temperature Hub, intrinsically safe

Model(s): 6000 followed by NV or DV followed by S2, followed by UN or 4AN, followed by WH, CK or XX, where XX can be any 2 alpha-numeric combination, followed by AC, AH, DC or DH.

Model(s): Manifold 6000-MAN-DV-xx, Model 6000-UIC-xx may be followed by additional numbers or letters

Class I, Division 1, Group A, B, C and D, Class II, Division 1, Group E, F and G, Class III, Division 1, Purge and pressurization control system component kit

Model(s): Model 6000-TSEN-01 Temperature Sensors

Model(s): Model EPV-6000-xx-xx Relief Vent may be followed by additional numbers or letters, intrinsically safe

Model(s): Manifold Model 6000-MAN-DV-xx may be followed by additional numbers or letters.

Model(s): Models 6000-TEMP-01 Temperature Hub

Model(s): Models 6000 followed by EXKIT followed by AC, AH, DC or DH, followed by XX, where XX can be any 2 alpha-numeric combination, may be followed by GD. Device provides intrinsically safe circuits

Model(s): User Interface 6000-UIC-xx may be followed by additional numbers or letters.

Class I, Division 1, Group A, B, C and D, Manifold

Model(s): 6000-MAN-DV-xx may be followed by additional numbers or letters, intrinsically safe when installed

Class I, Division 1, Group A, B, C and D, Class I, Division 1, Group A, B, C and D, Class II, Division 1, Group E, F and G, Class III, Division 1, Group A, B, C and D, Class I, Division 1, Group A, B, C and D, optional I.S. Termination Board DIN mounted

Model(s): Model 6000-ISB-XX, Models 6000-ISB-XX, 6000-ISB-XX

Class I, Division 1, Group A, B, C and D, Class II, Division 1, Group E, F and G, Class III, Division 1, Temperature Hub

Model(s): 6000-TEMP-01

Class I, Division 1, Group A, B, C and D, Class II, Division 1, Group E, F and G, Class III, Division 1, Temperature Sensors

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-2341539-1
Report reference: E184741-20080226
Issue Date: 2026-02-20

Model(s): Model 6000-TSEN-01

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



Certificate of Compliance

Certificate Number(s):

UL-CA-2539675-0
UL-CA-2335941-1

Report Reference:

E184741-20080226

Issue Date:

2026-02-20

Issued to:

Pepperl+Fuchs SE
Lilienthalstrasse 200, Mannheim, 68307, DE

This certificate confirms that representative samples of:

RFPZ7 - Purging and Pressurizing Controls and Accessories for Use in Zone Classified Hazardous Locations Certified for Canada

RFPW7 - Purging and Pressurizing Controls and Accessories for Use in Hazardous Locations Certified for Canada

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CSA C22.2 No. 60079-2, Edition: 2, Issue Date: 2016-06

NFPA 496, Edition 2024

CSA C22.2 NO. 25, 4th Ed., Issue Date: 2017-07-01

CSA C22.2 No. 30, Edition 4, Issued 2020-04-01

CSA C22.2 NO. 157-92, 3rd Ed., Issue Date: 1992-06-01,

Revision Date: 2003-06-01

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-CA-2539675-0, UL-CA-2335941-1
Report reference: E184741-20080226
Issue Date: 2026-02-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Class I, Division 1, Group A, B, C and D

Model(s): EPV-6000-xx-xx Relief Vent, may be followed by additional numbers or letters, intrinsically safe when installed

Model(s): 6000-TSEN-01 Temperature Sensors intrinsically safe when installed

Model(s): Model 6000 followed by EXKIT followed by AC, AH, DC or DH, followed by XX, where XX can be any 2 alpha-numeric combination, may be followed by "blank" or GO. Device provides intrinsically safe circuits

Model(s): 6000-UIC-xx may be followed by additional numbers or letters, intrinsically safe when installed

Class I, Division 1, Group A, B, C and D, Class II, Division 1, Group E, F and G, Class III, Division 1

Model(s): Model EPV-6000-xx-xx Relief Vent, may be followed by additional numbers or letters, intrinsically safe when installed

Model(s): Model 6000-TEMP-01 Temperature Hub, intrinsically safe

Model(s): 6000 followed by NV or DV followed by S2, followed by UN or 4AN, followed by WH, CK or XX, where XX can be any 2 alpha-numeric combination, followed by AC, AH, DC or DH.

Model(s): Manifold 6000-MAN-DV-xx, Model 6000-UIC-xx may be followed by additional numbers or letters

Class I, Division 1, Group A, B, C and D, Class II, Division 1, Group E, F and G, Class III, Division 1, Purge and pressurization control system component kit

Model(s): Model 6000-TSEN-01 Temperature Sensors

Model(s): Model EPV-6000-xx-xx Relief Vent may be followed by additional numbers or letters, intrinsically safe

Model(s): Manifold Model 6000-MAN-DV-xx may be followed by additional numbers or letters.

Model(s): Models 6000-TEMP-01 Temperature Hub

Model(s): Models 6000 followed by EXKIT followed by AC, AH, DC or DH, followed by XX, where XX can be any 2 alpha-numeric combination, may be followed by GD. Device provides intrinsically safe circuits

Model(s): User Interface 6000-UIC-xx may be followed by additional numbers or letters.

Class I, Division 1, Group A, B, C and D, Manifold

Model(s): 6000-MAN-DV-xx may be followed by additional numbers or letters, intrinsically safe when installed

Class I, Division 1, Group A, B, C and D, Class I, Division 1, Group A, B, C and D, Class II, Division 1, Group E, F and G, Class III, Division 1, Group A, B, C and D, Class I, Division 1, Group A, B, C and D, optional I.S. Termination Board DIN mounted

Model(s): Model 6000-ISB-XX, Models 6000-ISB-XX, 6000-ISB-XX

Class I, Division 1, Group A, B, C and D, Class II, Division 1, Group E, F and G, Class III, Division 1, Temperature Hub

Model(s): 6000-TEMP-01

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-CA-2539675-0, UL-CA-2335941-1
Report reference: E184741-20080226
Issue Date: 2026-02-20

Class I, Division 1, Group A, B, C and D, Class II, Division 1, Group E, F and G, Class III, Division 1, Temperature Sensors

Model(s): Model 6000-TSEN-01

Zone 1, Ex db ib [ib Gb] [pxb Gb] IIC T4 Gb, Purge and pressurization control system component kit

Model(s): Model 6000 followed by EXKIT followed by AC, AH, DC or DH, followed by XX, where XX can be any 2 alpha-numeric combination, may be followed by "blank" or GO. Device provides intrinsically safe circuits

Zone 1, Ex db ib [ib Gb] [pxb Gb] IIC T4 Gb, Zone 21, Ex ib tb [ib Db] [pxb Db] IIIC T60°C Db, Purge and pressurization control system component kit

Model(s): 6000 followed by NV or DV followed by S2, followed by UN or 4AN, followed by WH, CK or XX, where XX can be any 2 alpha-numeric combination, followed by AC, AH, DC or DH.

Zone 1, Ex db [ib Gb][pxb Gb] IIC T4 Gb, Zone 21, Ex tb [ib Db] [pxb Db] IIIC T80°C Db, Purge and pressurization control system component kit

Model(s): Model 6000 GO followed by EXKIT followed by AC, AH, DC or DH, followed by XX, where XX can be any 2 alpha-numeric combination, may be followed by GO. Device provides intrinsically safe circuits

Zone 1, Ex db [ib Gb] [pxb Gb] IIC T4 Gb, Zone 21, Ex tb [ib Db] [pxb Db] IIIC T80°C Db, Purge and pressurization control system component kit

Model(s): Models 6000 followed by EXKIT followed by AC, AH, DC or DH, followed by XX, where XX can be any 2 alpha-numeric combination, may be followed by GD. Device provides intrinsically safe circuits