

Certificate of Compliance

Certificate Number(s):

UL-US-26105708-0
UL-US-2341724-1

Report Reference:

E184741-20180914

Issue Date:

2026-05-05

Issued to:

Pepperl+Fuchs SE
Lilienthalstrasse 200, Mannheim, 68307, DE

This certificate confirms that representative samples of:

RFPZ - Purging and Pressurizing Controls and Accessories for Use in Zone Classified Hazardous Locations

RFPW - Purging and Pressurizing Controls and Accessories for Use in Hazardous Locations

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 60079-0, Edition 7, Issue Date 2019-03-26, Revision Date 2024-07-19

UL 60079-7:2017 (R2025), Edition 5, Issue Date 2017-02-24, Revision Date 2025-09-10

UL 60079-15, Edition 5, Issue Date 2020-04-07, Revision Date 2024-06-27

UL 60079-31:2025, Edition 3, Issue Date 2025-09-17

UL 61010-1, 3rd Ed., Issue Date: 2012-05-11, Revision Date: 2019-07-19

UL 60079-2:2017 (R2025), Edition 6, Issue Date 2017-06-02, Revision Date 2025-12-05

NFPA 496, Edition 2024

UL 121201, Edition 9, Issue Date 2017-09-15, Revision Date 2025-07-30

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-26105708-0, UL-US-2341724-1
Report reference: E184741-20180914
Issue Date: 2026-05-05

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-26105708-0, UL-US-2341724-1
Report reference: E184741-20180914
Issue Date: 2026-05-05

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Class I, Division 2, Group A, B, C and D, Class II, Division 2, Group F and G

Model(s): Type Z purge system, 7500 Series comprising Control Unit 7500... and associated accessories, Vent, Conduit Hub, Mounting Arrangement

Zone 2, Class I Zone 2 AEx ec nC [pzc Gc] IIC T6...T4 Gc, Zone 22, Zone 22 AEx tc [pzc Dc] IIIB T60°C...T80°C Dc

Model(s): Type Z purge system, 7500 Series comprising Control Unit 7500... and associated accessories, Vent, Conduit Hub, Mounting Arrangement

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



Certificate of Compliance

Certificate Number(s):

UL-CA-2677733-0
UL-CA-2336107-1

Report Reference:

E184741-20180914

Issue Date:

2026-05-05

Issued to:

Pepperl+Fuchs SE
Lilienthalstrasse 200, Mannheim, 68307, DE

This certificate confirms that representative samples of:

RFPZ7 - Purging and Pressurizing Controls and Accessories for Use in Zone Classified Hazardous Locations Certified for Canada

RFPW7 - Purging and Pressurizing Controls and Accessories for Use in Hazardous Locations Certified for Canada

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CSA C22.2 NO. 60079-0, Edition 4, Issue Date: 2019-02-01

CSA C22.2 No. 60079-2, Edition: 2, Issue Date: 2016-06

CSA C22.2 No. 60079-7, Edition 2, AMD 1, Issue Date 2016-10, Revision Date 2018-09

CSA C22.2 NO. 60079-15, 3rd Ed., Issue Date: 2018-11-01

CSA C22.2 No. 60079-31:25, Edition 3, Issue Date 2025-09-17

NFPA 496, Edition 2024

CSA C22.2 NO. 213-17, 3rd Ed., Issue Date: 2017-09-15,

Revision Date: 2021-04-01

CSA C22.2 No. 61010-1:12, Edition 3, Issue Date 2012-05,

Revision Date 2018-11

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-CA-2677733-0, UL-CA-2336107-1
Report reference: E184741-20180914
Issue Date: 2026-05-05

that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-CA-2677733-0, UL-CA-2336107-1
Report reference: E184741-20180914
Issue Date: 2026-05-05

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Class I, Division 2, Group A, B, C and D, Class II, Division 2, Group F and G

Model(s): Type Z purge system, 7500 Series *comprising Control Unit 7500... and associated accessories, Vent, Conduit Hub, Mounting Arrangement*

Zone 2, Ex ec nC [pzc Gc] IIC T6...T4 Gc X, Zone 22, Ex tc [pzc Dc] IIIC T60°C...T80°C Dc X

Model(s): Type Z purge system, 7500 Series *comprising Control Unit 7500... and associated accessories, Vent, Conduit Hub, Mounting Arrangement*

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

