

CERTIFICATE OF COMPLIANCE

Certificate Number E482035
Report Reference E482035-20191031
Issue Date 2019-DECEMBER-12

Issued to: Pepperl+Fuchs Manufacturing Inc
502 Cane Island Pky
Katy, TX 77494

This certificate confirms that representative samples of Enclosures For Use In Hazardous Locations
Refer to the Addendum Page for Models

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 50E and CSA C22.2 NO. 94.2-15, Enclosures for Electrical Equipment, Environmental Considerations.
UL 50 and CAN/CSA C22.2 No. 94.1-15, Enclosures for Electrical Equipment, Non-Environmental Considerations.
UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations.
CSA C22.2 No. 25, Enclosures for Use in Class II, Division 1, Groups E, F, and G Hazardous Locations.
CSA C22.2 No. 30-M1986, Explosion-Proof Enclosures for Use in Class I Hazardous Locations; with General Instruction No. 2:1988-11.

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E482035
Report Reference E482035-20191031
Issue Date 2019-DECEMBER-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Explosion-proof enclosures Series EJB, may be followed by X, followed by 0, 3, 4, 6, 8, 10, 11, 15, 17 or 18, followed by A, B or Q, may be followed by W0, W1, W2, W3, or W7, followed by U for use in Hazardous Locations, Class I, Groups B, C and D; Class II, Groups E, F and G.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

