

Pepperl+Fuchs GmbH  
Lilienthalstraße 200  
68307 Mannheim  
Germany  
Phone +49 621 776-0  
Fax +49 621 776-1000

No. / Nr.: DOC-0048D  
Date / Datum: 2019-01-14

Copyright Pepperl+Fuchs  
www.pepperl-fuchs.com



### Declaration of conformity / Konformitätserklärung

We, Pepperl+Fuchs GmbH declare under our sole responsibility that the **products** listed below are in conformity with the listed **European Directives** and **standards**.

Die Pepperl+Fuchs GmbH erklärt hiermit in alleiniger Verantwortung, dass die unten gelisteten **Produkte** den genannten **Europäischen Richtlinien** und **Normen** entsprechen.

### Products / Produkte

Product / Produkt	Item number	Description / Beschreibung
KFD2-CD-EX1.32-8	295077	Current driver
KFD2-CD-EX1.32-9	295078	Current driver
KFD2-CD-EX1.32	284622	Current driver
KFD2-CD-EX1.32-1	295000	Current driver
KFD2-CD-EX1.32-10	295002	Current driver
KFD2-CD-EX1.32-12	295021	Current driver
KFD2-CD-EX1.32-13	295070	Current driver
KFD2-CD-EX1.32-15	295071	Current driver
KFD2-CD-EX1.32-2	295072	Current driver
KFD2-CD-EX1.32-21	295073	Current driver
KFD2-CD-EX1.32-3	295074	Current driver
KFD2-CD-EX1.32-5	295075	Current driver
KFD2-CD-EX1.32-6	295076	Current driver

### Directives and Standards / Richtlinien und Normen

EU-Directive EU-Richtlinie	Standards Normen
ATEX 2014/34/EU (L96/309-356)	EN 60079-0/A11:2013-11 EN 60079-0:2012-08 EN 60079-11:2012-01 EN 60079-15:2010-05
EMC 2014/30/EU (L96/79-106)	EN 61326-1:2013-01
RoHS 2011/65/EU (L174/88-110)	EN 50581:2012-09

### Affixed CE Marking / Angebrachte CE-Kennzeichnung



### Signatures / Unterschriften

Mannheim, 2019-01-14

ppa. M. Kessler i.V. S. Pflüger

ppa. Michael Kessler

i.V. Stefan Pflüger

Executive Vice President Components &amp; Technology

Product Portfolio Manager Interface Technology

### ANNEX EMC

The products listed above fulfill the immunity test requirements for equipment intended for use in industrial locations.

Die oben gelisteten Produkte erfüllen die Störfestigkeits-Prüfanforderungen an Betriebsmittel, die zum Gebrauch in industriellen Bereichen vorgesehen sind.

### ANNEX ATEX

Notified Body QM-System / Notifizierte Stelle des QM-Systems

Physikalisch Technische Bundesanstalt (0102)

Bundesallee 100

38116 Braunschweig

Germany

### Marking and Certificates / Kennzeichnung und Zertifikate

Marking Kennzeichnung	Certificate Zertifikat	Issuer ID Aussteller ID
  	BAS 02 ATEX 7203X	1180
	TÜV 99 ATEX 1499X	TUN

### Key for Issuer ID / Schlüssel zur Aussteller ID

ID	Issuer / Aussteller
TUN	TÜV NORD CERT GmbH Langemarckstraße 20 45141 Essen Germany
1180	BASEEFA - SGS Rockhead Business Park Staden Lane SK17 9RZ Buxton; Derbyshire Great Britain

Pepperl+Fuchs GmbH declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the essential health and safety requirements. The products still comply with the ATEX Directive. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.

Die Pepperl+Fuchs GmbH erklärt hiermit, dass die Produkte nur von kleineren oder formalen Änderungen in Bezug auf die neue Ausgabe der Normen betroffen sind. Diese Änderungen sind nicht relevant für die Konformität mit den wesentlichen Gesundheits- und Sicherheitsanforderungen. Die Produkte erfüllen nach wie vor die ATEX-Richtlinie. Diese Erklärung gilt auch, wenn die Kennzeichnung und die Zertifikate der aufgeführten Geräte vorangegangenen Normenständen entsprechen.