

Pepperl+Fuchs GmbH  
Lilienthalstraße 200  
68307 Mannheim  
Germany  
Phone +49 621 776-0  
Fax +49 621 776-1000

No. / Nr.: DOC-0756B  
Date / Datum: 2017-06-19

Copyright Pepperl+Fuchs  
www.pepperl-fuchs.com



### Declaration of conformity / Konformitätserklärung

We, Pepperl+Fuchs GmbH declare under our sole responsibility that the **products** listed below are in conformity with the listed **European Directives** and **standards**.

Die Pepperl+Fuchs GmbH erklärt hiermit in alleiniger Verantwortung, dass die unten gelisteten **Produkte** den genannten **Europäischen Richtlinien** und **Normen** entsprechen.

### Products / Produkte

Product / Produkt	Item number	Description / Beschreibung
HD2-DM-A	131000	Diagnostic module advanced
HD2-DM-B	131001	Diagnostic module basic
HD2-DM-BU	208187	Diagnostic module basic
HD2-DM-A.RO	200354	Diagnostic module advanced with relay output

### Directives and Standards / Richtlinien und Normen

EU-Directive EU-Richtlinie	Standards Normen
2014/30/EU (EMC) (L96/79-106)	EN 61326-1:2013
2014/34/EU (ATEX) (L96/309-356)	EN 60079-0:2012 + A11:2013 EN 60079-11:2012 EN 60079-15:2010
2011/65/EU (RoHS) (L174/88-110)	EN 50581:2012-09

### Affixed CE Marking / Angebrachte CE-Kennzeichnung



### Signatures / Unterschriften

Mannheim, 2017-06-19

ppa. M. Kessler

ppa. Michael Kessler  
Vice President – Business Unit  
Components & Technology

i.V. Gunther Rogoll

Manager - Product Group Fieldbus  
Technology

### ANNEX ATEX

#### Marking and Certificates / Kennzeichnung und Zertifikate

Products / Produkte	All products listed above / Alle oben gelisteten Produkte	
Marking Kennzeichnung	Certificate Zertifikat	Issuer ID Aussteller ID
II 3G	TÜV 04 ATEX 2500 X	TÜV

#### Key for Issuer ID / Schlüssel zur Aussteller ID

ID	Issuer / Aussteller
TÜV	TÜV NORD CERT GmbH Langemarkstraße 20 45141 Essen Germany