

Pepperl+Fuchs SE
Lilienthalstraße 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No. / Nr.: DOC-0756C
Date / Datum: 2021-11-25

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com



Declaration of conformity / Konformitätserklärung

We, Pepperl+Fuchs SE declare under our sole responsibility that the **products** listed below are in conformity with the listed **European Directives and standards**.

Die Pepperl+Fuchs SE erklärt hiermit in alleiniger Verantwortung, dass die unten gelisteten Produkte den genannten Europäischen Richtlinien und Normen entsprechen.

Products / Produkte

| Product / Produkt | Item number | Description / Beschreibung |
|-------------------|-------------|----------------------------|
| HD2-DM-A | 131000 | Advanced Diagnostic Module |
| HD2-DM-A.RO | 200354 | AD Modul, Relaisausgang |
| HD2-DM-B | 131001 | Diagnostic Module basic |

Directives and Standards / Richtlinien und Normen

| EU-Directive EU-Richtlinie | Standards Normen |
|----------------------------------|---|
| ATEX 2014/34/EU (L96/309-356) | EN 60079-11:2012-01 EN 60079-15:2010-05 EN IEC 60079-0/AC:2020-02 EN IEC 60079-0:2018-07 |
| EMC 2014/30/EU (L96/79-106) | EN 61326-1:2013-01 |
| RoHS 2011/65/EU (L174/88-110) | EN IEC 63000:2018-12 |

Affixed CE Marking / Angebrachte CE-Kennzeichnung



Signatures / Unterschriften

Mannheim, 2021-11-25

ppa. Michael Kessler
ppa. Michael Kessler

Executive Vice President Components & Technology

i.V. Norbert Lindner

i.V. Norbert Lindner

Continuation Manager Value Engineering

ANNEX ATEX

Marking and Certificates / Kennzeichnung und Zertifikate

| Marking Kennzeichnung | Certificate Zertifikat | Issuer ID Aussteller ID |
|--------------------------|---------------------------|----------------------------|
| II 3 G | TÜV 04 ATEX 2500X | TUN |

Key for Issuer ID / Schlüssel zur Aussteller ID

| ID | Issuer / Aussteller |
|-----|--|
| TUN | TÜV NORD CERT GmbH Langemarkstraße 20 45141 Essen Germany |

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the essential health and safety requirements. The products still comply with the ATEX Directive. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.

Die Pepperl+Fuchs SE erklärt hiermit, dass die Produkte nur von kleineren oder formalen Änderungen in Bezug auf die neue Ausgabe der Normen betroffen sind. Diese Änderungen sind nicht relevant für die Konformität mit den wesentlichen Gesundheits- und Sicherheitsanforderungen. Die Produkte erfüllen nach wie vor die ATEX-Richtlinie. Diese Erklärung gilt auch, wenn die Kennzeichnung und die Zertifikate der aufgeführten Geräte vorangegangenen Normenständen entsprechen.