

Pepperl+Fuchs GmbH
 Lilienthalstraße 200
 68307 Mannheim
 Germany
 Phone +49 621 776-0
 Fax +49 621 776-1000

No. / Nr.: DOC-2471
 Date / Datum: 2016-01-11

Copyright Pepperl+Fuchs
 www.pepperl-fuchs.com



■ Declaration of conformity / Konformitätserklärung

We, Pepperl+Fuchs GmbH declare under our sole responsibility that the products listed below are in conformity with section 5.7 "Simple apparatus" of EN 60079-11:2012.

Die Pepperl+Fuchs GmbH erklärt hiermit in alleiniger Verantwortung, dass die unten gelisteten Produkte dem Abschnitt 5.7 „Einfache elektrische Betriebsmittel“ der EN 60079-11:2012 entsprechen.

■ Products / Produkte

Product / Produkt	Item number	Description / Beschreibung
R-JB-I6	132755	Fieldbus Junction Box passive, Din-Rail mounting
F2-JB-I4.CG	122013	Fieldbus Junction Box passive in field enclosure, 4-channel, plastic cable glands
F2-JB-I4.CGB	122014	Fieldbus Junction Box passive in field enclosure, 4-channel, brass cable glands
F2-JB-I4.CGS	122015	Fieldbus Junction Box passive in field enclosure, 4-channel, stainless steel cable glands
F2-JB-I6.CG	122018	Fieldbus Junction Box passive in field enclosure, 6-channel, plastic cable glands
F2-JB-I6.CGB	122019	Fieldbus Junction Box passive in field enclosure, 6-channel, brass cable glands
F2-JB-I6.CGS	122020	Fieldbus Junction Box passive in field enclosure, 6-channel, stainless steel cable glands
F2-JB-I8.CG	122022	Fieldbus Junction Box passive in field enclosure, 8-channel, plastic cable glands
F2-JB-I8.CGB	118498	Fieldbus Junction Box passive in field enclosure, 8-channel, brass cable glands

This Declaration of Conformity is only valid in connection with the valid datasheet of Pepperl+Fuchs and the valid instruction of Pepperl+Fuchs.

Diese Konformitätserklärung gilt nur in Zusammenhang mit dem gültigen Pepperl+Fuchs Datenblatt und der gültigen Pepperl+Fuchs Betriebsanleitung.

According to the standard EN 60079-11:2012, these products have no additional marking.

Entsprechend der Norm EN 60079-11:2012 werden diese Produkte nicht zusätzlich gekennzeichnet.

■ Signatures / Unterschriften

Mannheim, 2016-01-11

i.V. Gunther Rogoll

Manager – Product Group Fieldbus Technology

DOC-2471 / 2016-01-11

i.A. Michael Oestreicher

NormExpert EX Fieldbus Technology