EU-Declaration of conformity

EU-Konformitätserklärung

en/de

Pepperl+Fuchs SE
Lilienthalstraße 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No. / *Nr.*: DOC-3097E
Date / *Datum*: 2025-05-13

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com

PEPPERL+FUCHS

Declaration of conformity / *Konformitätserklärung*

We, Pepperl+Fuchs SE declare under our sole responsibility that the **products** listed below are in conformity with the listed **European Directives** and **standards**.

*Die Pepperl+Fuchs SE erklärt hiermit in alleiniger Verantwortung, dass die unten gelisteten **Produkte** den genannten **Europäischen Richtlinien** und **Normen** entsprechen.*

Products / *Produkte*

Productfamily / *Produktfamilie*	**Item number /** Artikelnr.	**Description /** *Beschreibung*
PSU1100-J1-*	271722-*	VisuNet Power Supply for use in Zone 1/21

Directives and Standards / *Richtlinien und Normen*

EU-Directive *EU-Richtlinie*	**Standards** *Normen*
2014/30/EU (EMC) (L96/79-106)	EN 61000-6-4:2007+A1:2011 EN 61326-1:2013 (industrial location)
2014/34/EU (ATEX) (L96/309-356)	EN 60079-0:2018 EN 60079-5:2015 EN 60079-7:2015+A1:2018 EN 60079-31:2014
2011/65/EU (RoHS) (L174/88–110)	EN IEC 63000:2018

Affixed CE Marking / *Angebrachte CE-Kennzeichnung*

CE 2829

Signatures / *Unterschriften*

Mannheim, 2025-05-13

i.V. Roolf Wessels
Executive Vice President
ECOM+HMI

i.V. Predrag Bursac
Continuation Manager HMI
Business Unit HMI

ANNEX ATEX

Notified Body QM-System / ***Notifizierte Stelle des QM-Systems*****:**
Fiditas d.o.o. (2829)
Ulica Slavka Tomerlina 44
10361 Zagreb-Sesvete
Croatia

Marking and Certificates / ***Kennzeichnung und Zertifikate***

Products / *Produkte*	**PSU1100-J1-***	
Marking *Kennzeichnung*	Certificate *Zertifikat*	Issuer ID *Aussteller* ID
Ex II 2 G Ex II 2 D	BVS 16 ATEX E 098 X	0158

Key for Issuer ID / ***Schlüssel zur Aussteller ID***

ID	**Issuer /** *Aussteller*
0158	DEKRA Testing and Certification GmbH Handwerkstr. 15, 70565 Stuttgart Germany

ANNEX TYPE CODE

The „X“ marked letters of the type code are placeholders and can be replaced by the following code:
Die mit „X“ markierten Stellen im Typenschlüssel sind Platzhalter und können durch folgenden Schlüssel ersetzt werden:

PSU1100-J1-XX-XX			
Variable	**Feature**	**Option**	**Description**
PSU1100-J1-	Power Supply Unit Family	PSU1100- J1-	Power Supply Unit Family for IECEx & ATEX II 2 GD
XX-	Input	DC-	18 … 36 V DC
		AC-	115 / 230 V AC
XX	Options	N0	Standard
		XX	*Other options without impact on explosion protection*