

Pepperl+Fuchs SE
Lilienthalstrasse 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No.: DOC-4102B
Date: 2022-01-04

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com



Attestation of conformity

We, Pepperl+Fuchs SE declare under our sole responsibility that the **components** listed below are in conformity with the listed **European Directives** and standards when incorporated into products in accordance with the listed characteristics and instructions.

Family of components

Types	Description
GR.**.*.*	GFRP component approved empty Ex e enclosure

Directives and Standards

EU-Directive	Standards
2014/34/EU (ATEX) (L96/309-356)	EN 60079-0: 2018-07 EN 60079-7:2015-12/A1:2018-01 EN 60079-31: 2014-07
2011/65/EU (RoHS) (L174/88-110)	EN IEC 63000:2018-12

Characteristics and instructions for incorporation into products

The characteristics of these components and how they must be incorporated into products are specified in the certificate(s) and in the ANNEX INSTRUCTIONS.

Signatures

Mannheim, 2022-01-04

ppa. Hermann Best
Vice President EPE
Products & Solutions

i.V. Rainer Nägle
Manager Innovation Unit EPE
& Solutions

ANNEX ATEX

Notified Body QM-System

Physikalisch Technische Bundesanstalt (0102)
Bundesallee 100
38116 Braunschweig
Germany

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the essential health and safety requirements. The products still comply with the ATEX Directive. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.

Marking and Certificates

Certificate	CML 17ATEX3084U	
Marking	Types	Issuer ID
II 2 G II 2 D	GR Ex e enclosure	2776

Key for Issuer ID

ID	Issuer
2776	CML B.V Chamber of Commerce No 6738671 Hoogoorddreef 15 Amsterdam 1101 BA The Netherlands

ANNEX INSTRUCTIONS

Refer to IOM document 161369CM-09.