

■ ANNEX ATEX

Notified Body QM-System

Physikalisch Technische Bundesanstalt (0102)

Bundesallee 100

38116 Braunschweig

Germany

Pepperl+Fuchs SE
Lilienthalstrasse 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No.: DOC-4853A
Date: 2022-01-17

Marking and Certificates

Certificate	CML 20ATEX3118U	
Marking	Types	Issuer ID
⊕ II 2 G ⊕ II 2 D	SR Ex e enclosure	2776

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com



■ Attestation of conformity

We, Pepperl+Fuchs SE declare under our sole responsibility that the **components** listed below are in conformity with the listed **European Directives** and standards when incorporated into products in accordance with the listed characteristics and instructions.

■ Family of components

Types	Description
SR.**.**	Stainless steel component approved empty Ex e enclosure

■ Directives and Standards

EU-Directive <i>EU-Richtlinie</i>	Standards <i>Normen</i>
2014/34/EU (ATEX) (L96/309-356)	EN IEC 60079-0:2018-07 EN 60079-7:2015-12/A1:2018-01 EN 60079-31:2014-07
2011/65/EU (RoHS) (L174/88-110)	EN IEC 63000:2018-12

■ Characteristics and instructions for incorporation into products

The characteristics of these components and how they must be incorporated into products are specified in the certificate(s) and in the ANNEX INSTRUCTIONS.

■ Signatures

Mannheim, 2022-01-17

ppa. Hermann Best
Vice President EPE
Products & Solutions

i.V. Rainer Nägle
Manager Innovation Unit EPE &
Solutions

Key for Issuer ID

ID	Issuer
2776	CML B.V Chamber of Commerce No 6738671 Hoogoorddreef 15 Amsterdam 1101 BA The Netherlands

■ ANNEX INSTRUCTIONS

Refer to IOM document 161533CM-09.