

Pepperl+Fuchs SE
Lilienthalstrasse 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No: DOC-5294A
Date: 2021-07-21

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com



Declaration of conformity

We, Pepperl+Fuchs SE declare under our sole responsibility that the **products** listed below are in conformity with the listed **UK Regulations** as indicated below and amended by **UK SI 2019 No. 696**, and **standards**.

Products

| Product | Item number | Description |
|-------------|-------------|-------------|
| KFD0-HMS-16 | 231291 | HART Mux |
| KFD2-HMM-16 | 231289 | HART Mux |

Regulations and Standards

| UK Regulation | Standards |
|----------------------------|--|
| UK SI 2012 No. 3032 (RoHS) | EN IEC 63000:2018-12 |
| UK SI 2016 No. 1091 (EMC) | EN 61326-1:2013-01 |
| UK SI 2016 No. 1107 (EX) | EN 60079-15:2010-05 EN IEC 60079-0/AC:2020-02 EN IEC 60079-0:2018-07 |


Affixed UKCA Marking



Signatures

Mannheim, 2021-07-21


ppa. Michael Kessler
Executive Vice President Components
& Technology


i.V. Norbert Lindner
Continuation Manager Value Engineering


ANNEX UK SI 2016 No. 1091 (EMC)

The products listed above fulfill the immunity test requirements for equipment intended for use in industrial locations.

ANNEX UK SI 2016 No. 1107 (EX)

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the essential health and safety requirements. The products still comply with UK SI 2016 No. 1107. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.

Marking and Certificates

| Marking | Certificate | ID |
|--|-------------------|----|
|  II 3 G | PF 07 CERT 1143 X | PF |

Key for ID

| ID | Responsible Body |
|----|---|
| PF | Pepperl+Fuchs Lilienthalstrasse 200 68307 Mannheim Germany |