UK-Declaration of conformity

en

Pepperl+Fuchs SE Lilienthalstrasse 200 68307 Mannheim Germany Phone +49 621 776-0 Fax +49 621 776-1000

Copyright Pepperl+Fuchs www.pepperl-fuchs.com

FPEPPERL+FUCHS

No: DOC-5305

Date: 2021-07-22

Declaration of conformity

We, Pepperl+Fuchs SE declare under our sole responsibility that the **products** listed below are in conformity with the listed **UK Regulations** as indicated below and amended by **UK SI 2019 No. 696**, and **standards**.

Products

Product	Item num- ber	Description
KFD0-RSH-1.4S.PS2	224579	Relay module

Regulations and Standards

UK Regulation	Standards
UK SI 2012 No. 3032 (RoHS)	EN IEC 63000:2018-12
UK SI 2016 No. 1091 (EMC)	EN 61326-1:2013-01
UK SI 2016 No. 1101 (LV)	EN 61010-1:2010-10
UK SI 2016 No. 1107 (EX)	EN 60079-15:2010-05 EN IEC 60079-0/AC:2020-02 EN IEC 60079-0:2018-07

Affixed UKCA Marking



Signatures

Mannheim, 2021-07-22

ppa. Michael Kessler
Executive Vice President Components
& Technology

i.V. Udo Körner

Continuation Manager Value Engineering

ANNEX UK SI 2016 No. 1091 (EMC)

The products listed above fulfill the immunity test requirements for equipment intended for use in industrial locations.

ANNEX UK SI 2016 No. 1107 (EX)

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the essential health and safety requirements. The products still comply with UK SI 2016 No. 1107. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.

Marking and Certificates

•		
Marking	Certificate	ID
<a> II 3 G	PF15CERT3844 X	PF

Key for ID

ID	Responsible Body
PF	Pepperl+Fuchs Lilienthalstrasse 200 68307 Mannheim Germany

1/1