

Pepperl+Fuchs SE  
Lilienthalstraße 200  
68307 Mannheim  
Germany  
Phone +49 621 776-0  
Fax +49 621 776-1000

No. / Nr.: DOC-6908  
Date / Datum: 2022-10-19

Copyright Pepperl+Fuchs  
www.pepperl-fuchs.com



### Declaration of conformity / Konformitätserklärung

We, Pepperl+Fuchs SE declare under our sole responsibility that the **products** listed below are in conformity with the listed **European Directives** and **standards**.

Die Pepperl+Fuchs SE erklärt hiermit in alleiniger Verantwortung, dass die unten gelisteten **Produkte** den genannten **Europäischen Richtlinien** und **Normen** entsprechen.

### Products / Produkte

Product / Produkt	Item number	Description / Beschreibung
NCN8-18GM40-Z0-3G-3D-10M	70155937	Inductive sensor

### Directives and Standards / Richtlinien und Normen

EU-Directive EU-Richtlinie	Standards Normen
ATEX 2014/34/EU (L96/309-356)	EN 60079-31:2014-07 EN 60079-7:2015-12 EN IEC 60079-0:2018-07 EN IEC 60079-7/A1:2018-01
EMC 2014/30/EU (L96/79-106)	EN IEC 60947-5-2:2020-03
RoHS 2011/65/EU (L174/88-110)	EN IEC 63000:2018-12

### Affixed CE Marking / Angebrachte CE-Kennzeichnung



### Signatures / Unterschriften

Mannheim, 2022-10-19

ppa. Wolfgang Helm

ppa. Wolfgang Helm  
Director Business Unit Sensors

i.V. M. Ruppert

i.V. Manfred Ruppert  
Head of Global Product Management  
Customer Applications

### ANNEX ATEX

#### Marking and Certificates / Kennzeichnung und Zertifikate

Marking Kennzeichnung	Certificate Zertifikat	Issuer ID Aussteller ID
II 3 G	TÜV 20 ATEX 8523 X	TUR
II 3 D	TÜV 20 ATEX 8524 X	TUR

#### Key for Issuer ID / Schlüssel zur Aussteller ID

ID	Issuer / Aussteller
TUR	TÜV Rheinland Industrial Services GmbH Automation and Functional Safety (AFS) Am Grauen Stein 51105 Cologne Germany