

Pepperl+Fuchs SE
Lilienthalstrasse 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No: DOC-7077
Date: 2022-11-21

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com



Declaration of conformity

We, Pepperl+Fuchs SE declare under our sole responsibility that the **products** listed below are in conformity with the listed **UK Regulations** as indicated below and amended by **UK SI 2019 No. 696**, and **standards**.

Products

Product	Item number	Description
KFA5-DU-EX1.D	231210	Switch amplifier
KFA5-DWB-EX1.D	70159061	Speed Monitor
KFA5-DWB-EX1.D	231208	Speed monitor
KFA6-DU-EX1.D	231211	Switch amplifier
KFA6-DWB-EX1.D	70159060	Speed Monitor
KFA6-DWB-EX1.D	231207	Speed monitor
KFD2-DU-EX1.D	231212	Switch amplifier
KFD2-DWB-EX1.D	231203	Speed monitor
KFD2-DWB-EX1.D	70159058	Speed Monitor

Regulations and Standards

UK Regulation	Standards
Supplemental Standards	EN 61010-1/A1/AC:2019-04 EN 61010-1/A1:2019-02 EN 61010-1:2010-10
UK SI 2012 No. 3032 (RoHS)	EN IEC 63000:2018-12
UK SI 2016 No. 1091 (EMC)	EN 61326-1:2013-01
UK SI 2016 No. 1107 (EX)	EN 60079-11:2012-01 EN 60079-15:2010-05 EN IEC 60079-0/AC:2020-02 EN IEC 60079-0:2018-07

Affixed UKCA Marking



Signatures

Mannheim, 2022-11-21

ppa. Michael Kessler
ppa. Michael Kessler
Executive Vice President
Components & Technology

Udo Körner
i.V. Udo Körner
Continuation Manager
Value Engineering

ANNEX UK SI 2016 No. 1091 (EMC)

The products listed above fulfill the immunity test requirements for equipment intended for use in industrial locations.

ANNEX UK SI 2016 No. 1107 (EX)

Approved Body QM-System:

Eurofins E&E CML Limited (2503)
Newport Business Park - New Port Road
CH65 4LZ Ellesmere Port
United Kingdom

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the essential health and safety requirements. The products still comply with UK SI 2016 No. 1107. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.

Marking and Certificates

Marking	Certificate	ID
Ex II 3 G	TÜV 02 ATEX 1885X	TUN
Ex I (M1) Ex II (1) D Ex II (1) G	CML 22UKEX2509	2503

Key for ID

ID	Responsible Body
TUN	TÜV NORD CERT GmbH Am TÜV 1 45307 Essen Germany
2503	Eurofins E&E CML Limited Newport Business Park - New Port Road CH65 4LZ Ellesmere Port United Kingdom