

Pepperl+Fuchs SE
 Lilienthalstrasse 200
 68307 Mannheim
 Germany
 Phone +49 621 776-0
 Fax +49 621 776-1000

No: DOC-B0G1A
 Date: 2023-02-21

Copyright Pepperl+Fuchs
 www.pepperl-fuchs.com



Declaration of conformity

We, Pepperl+Fuchs SE declare under our sole responsibility that the **products** listed below are in conformity with the listed **UK Regulations** as indicated below and amended by **UK SI 2019 No. 696**, and **standards**.

Product family

Productfamily / Produktfamilie	Description / Beschreibung
EPV-6000-xx-xx	Enclosure protection valve
EPV-6500-xx-xx	

The [X] marked letters of the type code are placeholders and can be replaced by the code described in ANNEX TYPE CODE.

Regulations and Standards

UK Regulation	Standards
UK SI 2016 No. 1091 (EMC)	EN 61000-6-2:2005 EN 61326-1:2013
UK SI 2016 No. 1107 (EX)	EN IEC 60079-0:2018 EN 60079-2:2014 EN 60079-11:2012
UK SI 2012 No. 3032 (RoHS)	EN IEC 63000:2018

Affixed UKCA Marking



Signatures

Mannheim, 2023-02-21

ppa. Michael Kessler
 ppa. Michael Kessler
 Executive Vice President Components & Technology

Brent Dean
 i.V. Brent Dean
 Purge Portfolio Manager – Purge and Pressurization

ANNEX UK SI 2016 No. 1107 (EX)

Approved Body QM-System:

EUROFINS E&E CML LIMITED (2503)
 Newport Business Park - New Port Road
 CH65 4LZ Ellesmere Port
 United Kingdom

Marking and Certificates

Marking	Certificate	ID
II 2 D II 2 G	UL21UKEX2016X	0843

Key for ID

ID	Responsible Body
0843	UL International (UK) LTD UL Unit 1 - 3 Horizon Wade Road Kingsland Business Park Basingstoke RG24 8AH United Kingdom

ANNEX TYPE CODE

The [X] marked letters of the type code are placeholders and can be replaced by the following code:

EPV-6000	XX	XX
EPV-6000- basic model for use with model 6000 purge system EPV-6500- basic model for use with model 6500 purge system	AA- All aluminum SS-Stainless	Any alphanumeric combination that identifies a particular valve style and system address.