

Pepperl+Fuchs SE  
Lilienthalstraße 200  
68307 Mannheim  
Germany  
Phone +49 621 776-0  
Fax +49 621 776-1000

No. / Č.: **DOC-0268E**  
Date / Dátum: **2023-03-06**

Copyright Pepperl+Fuchs  
www.pepperl-fuchs.com



### Declaration of conformity / Vyhlásenie o zhode

We Pepperl+Fuchs SE declare under our sole responsibility that the products listed below are in conformity with the listed European Directives and standards.

My, spoločnosť Pepperl+Fuchs SE, vyhlasujeme na našu výhradnú zodpovednosť, že produkty uvedené nižšie sú v súlade s uvedenými európskymi smernicami a normami.

### Products / Produkty

Products Produkty	Itemnumber Číslo položky	Description Opis
R4D0-FB-IA10.0	239931	Fieldbus Barrier
R4D0-FB-IA10.1	259284	Fieldbus Barrier
R4D0-FB-IA12.0	239935	Fieldbus Barrier
R4D0-FB-IA12.1	259325	Fieldbus Barrier
R4D0-FB-IA8.0	239936	Fieldbus Barrier
R4D0-FB-IA8.1	259283	Fieldbus Barrier

### Directives and Standards / Smernice a normy

EU-Directive Smernice EÚ	Standards Normy
ATEX 2014/34/EU (L96/309-356)	EN IEC 60079-0/AC:2020-02 EN 60079-18:2015-04 EN IEC 60079-0:2018-07 EN 60079-7:2015-12 EN 60079-11:2012-01 EN IEC 60079-7/A1:2018-01 EN 60079-18/A1:2017-12
EMC 2014/30/EU (L96/79-106)	EN 61326-1:2013-01
RoHS 2011/65/EU (L174/88-110)	EN IEC 63000:2018-12

### Affixed CE Marking / Priložené označenie CE



*ppa. M. Kessler* i.v. *Norbert Lindner*

ppa. Michael Kessler  
Executive Vice President  
Components & Technology

i.V. Norbert Lindner  
Continuation Manager Value Engineering

The English version represents the signed original.  
Podpísaný originál dokumentu je v anglickej verzii.

### ANNEX ATEX / PRÍLOHA ATEX

Notified Body QM-System / Notifikovaný orgán – Systém manažérstva kvality (QM-System)

Physikalisch Technische Bundesanstalt (0102)  
Bundesallee 100  
38116 Braunschweig  
Germany

### Marking and Certificates / Označenia a certifikáty

Marking Označenie	Certificate Certifikát	Issuer ID Emitent ID
⊕ II (1) D ⊕ II (M1) ⊕ II 2 (1) G	BVS 13 ATEX E 121 X	0158

### Key for Issuer ID / Kľúč emitenta ID

ID	Issuer Emitent
0158	DEKRA Testing and Certification GmbH Handwerkstraße 15 70565 Stuttgart Germany

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the essential health and safety requirements. The products still comply with the ATEX Directive. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards. Spoločnosť Pepperl+Fuchs SE vyhlasuje, že na produktoch sa vykonali iba menšie alebo formálne úpravy vzhľadom na nové vydanie noriem. Tieto úpravy nie sú relevantné pre súlad s požiadavkami na ochranu zdravia a bezpečnosti. Tieto produkty sú stále v súlade so smernicou ATEX. Toto vyhlásenie je platné aj vtedy, ak označenie a certifikáty uvedených zariadení zodpovedajú predchádzajúcim vydaniám noriem.