

Pepperl+Fuchs SE  
Lilienthalstraße 200  
68307 Mannheim  
Germany  
Phone +49 621 776-0  
Fax +49 621 776-1000

No. / N.: **DOC-0592C**  
Date / Data: **2023-08-16**

Copyright Pepperl+Fuchs  
www.pepperl-fuchs.com



### Declaration of conformity / Dichiarazione di conformità

We Pepperl+Fuchs SE declare under our sole responsibility that the products listed below are in conformity with the listed European Directives and standards.

La sottoscritta Pepperl+Fuchs SE dichiara sotto la propria esclusiva responsabilità che i prodotti elencati di seguito sono conformi alle direttive e alle norme europee citate.

### Products / Prodotti

Products Prodotti	Itemnumber N° articolo	Description Descrizione
KHA6-SH-EX1	046904	Safety switch amplifier

### Directives and Standards / Direttive e norme

EU-Directive Direttiva UE	Standards Norme
ATEX 2014/34/EU (L96/309-356)	EN IEC 60079-0/AC:2020-02 EN 60079-11:2012-01 EN IEC 60079-0:2018-07
EMC 2014/30/EU (L96/79-106)	EN 61326-1:2013-01
LVD 2014/35/EU (L96/357-374)	EN 61010-1:2010-10 EN 61010-1/A1:2019-02 EN 61010-1/A1/AC:2019-04
MD 2006/42/EC (L157/24-86)	EN ISO 13849-1:2015-12
RoHS 2011/65/EU (L174/88-110)	EN IEC 63000:2018-12

### Affixed CE Marking / Marcatura CE apposta



### Signatures / Firme

Mannheim, 2023-08-16

ppa. Michael Kessler  
Executive Vice President  
Components & Technology

i.V. Udo Körner  
Continuation Manager Value Engineering

The English version represents the signed original.  
La versione inglese rappresenta l'originale firmato.

### ANNEX EMC / ALLEGATO EMC

The products listed above fulfill the immunity test requirements for equipment intended for use in industrial locations.  
I prodotti sopra elencati soddisfano i requisiti per i test di immunità per le apparecchiature con destinazione d'uso in località industriali.

### ANNEX ATEX / ALLEGATO ATEX

#### Notified Body QM-System / Organismo notificato sistema QM

Physikalisch Technische Bundesanstalt (0102)  
Bundesallee 100  
38116 Braunschweig  
Germany

#### Marking and Certificates / Marcatura e certificati

Marking Marcatura	Certificate Certificato	Issuer ID Numero di identificazione dell'Ente notificatore
⊕ I (M1) ⊕ II (1) D ⊕ II (1) G	PTB 00 ATEX 2043	0102

#### Key for Issuer ID / Chiave per numero di identificazione dell'Ente notificatore

ID	Issuer Ente notificatore
0102	Physikalisch Technische Bundesanstalt Bundesallee 100 38116 Braunschweig Germany

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the essential health and safety requirements. The products still comply with the ATEX Directive. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.  
Pepperl+Fuchs SE dichiara che i prodotti sono interessati solo da modifiche di minore entità o formali rispetto alla nuova edizione delle norme. Queste modifiche non interessano la conformità ai requisiti essenziali per la sicurezza e la salute. I prodotti sono ancora conformi alla direttiva ATEX. Questa dichiarazione è valida anche se la marcatura e i certificati dei dispositivi elencati corrispondono a precedenti edizioni delle norme.