

Pepperl+Fuchs SE
Lilienthalstraße 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No. / Nr.: **DOC-1039D**
Date / Dato: **2024-06-12**

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com



Declaration of Conformity / Overensstemmelseserklæring

We, Pepperl+Fuchs SE, declare under our sole responsibility that the products listed below are in conformity with the listed European Directives, Regulations, and standards.

Vi, Pepperl+Fuchs SE, erklærer hermed under eneansvar, at de nedenfor anførte produkter er i overensstemmelse med de angivne EU-direktiver og -standarder.

Products / Produkter

Product Produkt	Itemnumber Varenummer	Description Beskrivelse
LB3106A	254716	Transmitter Power Supply
LB4101A2	254722	Analog Output
LB4102A2	254723	Analog Output
LB4102C2	254724	Analog Output
LB4104A2	254725	Analog Output
LB4105A2	254726	Analog Output
LB4105C2	254727	Analog Output
LB4106A	254729	Analog Output
LB4106C	254730	Analog Output
LB7104A	254847	Universal Analog I/O
LB7104E	70176490	Universal Analog I/O

Directives and Standards / Direktiver og standarder

EU Directive EU-direktiv	Standards Standarder
ATEX 2014/34/EU (L96/309-356)	EN 60079-11:2012-01 EN IEC 60079-0/AC:2020-02 EN 60079-15:2010-05 EN IEC 60079-0:2018-07
EMC 2014/30/EU (L96/79-106)	EN 61326-1:2013-01
RoHS 2011/65/EU (L174/88-110)	EN IEC 63000:2018-12

Affixed CE Marking / Anbragt CE-mærkning



ppa. Michael Kessler i.v. Norbert Lindner

ppa. Michael Kessler
Executive Vice President
Components & Technology

i.V. Norbert Lindner
Continuation Manager Value Engineering

The English version represents the signed original.
Den engelske version repræsenterer den underskrevne original.

ANNEX ATEX / ATEX-BILAG

Notified Body QM System / Bemyndiget organ, kvalitetsstyrings-system

Physikalisch Technische Bundesanstalt (0102)
Bundesallee 100
38116 Braunschweig
Germany

Marking and Certificates / Mærkning og certifikater

Marking Mærkning	Certificate Certifikat	ID
⊕ I (M1) ⊕ II (1) D ⊕ II 3 (1) G	BVS 11 ATEX E 116 X	0158

Key for ID / ID-nøgle

ID	Responsible Body Ansvarligt organ
0158	DEKRA Testing and Certification GmbH Handwerkstraße 15 70565 Stuttgart Germany

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the Essential Health and Safety Requirements. The products still comply with the ATEX Directive. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.

Pepperl+Fuchs SE erklærer hermed, at produkterne kun udsættes for mindre eller formelle ændringer i henhold til opdaterede udgaver af standarderne. Disse ændringer påvirker ikke overholdelsen af de væsentlige sikkerheds- og sundhedskrav. Produkterne er stadig i overensstemmelse med ATEX-direktivet. Denne erklæring er også gældende, hvis mærkning og certifikater for de anførte enheder svarer til tidligere udgaver af standarderne.