

Pepperl+Fuchs SE  
Lilienthalstraße 200  
68307 Mannheim  
Germany  
Phone +49 621 776-0  
Fax +49 621 776-1000

No. / Nr.: **DOC-1039D**  
Date / Datum: **2024-06-12**

Copyright Pepperl+Fuchs  
www.pepperl-fuchs.com



### Declaration of Conformity / Conformiteitsverklaring

We, Pepperl+Fuchs SE, declare under our sole responsibility that the products listed below are in conformity with the listed European Directives, Regulations, and standards.

*Wij, Pepperl+Fuchs SE, verklaren geheel onder eigen verantwoordelijkheid, dat de hieronder vermelde producten aan de geldende Europese richtlijnen, verordeningen en normen voldoen.*

### Products / Producten

Product	Itemnumber Itemnummer	Description Beschrijving
LB3106A	254716	Transmitter Power Supply
LB4101A2	254722	Analog Output
LB4102A2	254723	Analog Output
LB4102C2	254724	Analog Output
LB4104A2	254725	Analog Output
LB4105A2	254726	Analog Output
LB4105C2	254727	Analog Output
LB4106A	254729	Analog Output
LB4106C	254730	Analog Output
LB7104A	254847	Universal Analog I/O
LB7104E	70176490	Universal Analog I/O

### Directives and Standards / Richtlijnen en normen

EU Directive EU-richtlijn	Standards Normen
ATEX 2014/34/EU (L96/309-356)	EN 60079-11:2012-01 EN IEC 60079-0/AC:2020-02 EN 60079-15:2010-05 EN IEC 60079-0:2018-07
EMC 2014/30/EU (L96/79-106)	EN 61326-1:2013-01
RoHS 2011/65/EU (L174/88-110)	EN IEC 63000:2018-12

### Affixed CE Marking / Aangebrachte CE-markering



*ppa. M. Kessler* i.v. Norbert Lindner

ppa. Michael Kessler  
Executive Vice President  
Components & Technology

i.V. Norbert Lindner  
Continuation Manager Value Engineering

The English version represents the signed original.  
*De Engelstalige versie is het ondertekende origineel.*

### ANNEX ATEX

#### Notified Body QM System / Erkend organisme QM-systeem

Physikalisch Technische Bundesanstalt (0102)  
Bundesallee 100  
38116 Braunschweig  
Germany

#### Marking and Certificates / Markering en certificaten

Marking Markering	Certificate Certificaat	ID Identificatie- nummer
⊕ I (M1) ⊕ II (1) D ⊕ II 3 (1) G	BVS 11 ATEX E 116 X	0158

#### Key for ID / Sleutel voor identificatie

ID Identificatie- nummer	Responsible Body Verantwoordelijk organisme
0158	DEKRA Testing and Certification GmbH Handwerkstraße 15 70565 Stuttgart Germany

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the Essential Health and Safety Requirements. The products still comply with the ATEX Directive. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.

*Pepperl+Fuchs SE verklaart dat alleen kleine of formele wijzigingen uit nieuwe uitgaven van normen van toepassing zijn op de producten. Deze wijzigingen zijn niet relevant voor de naleving van essentiële gezondheids- en veiligheidsvoorschriften. De producten voldoen nog steeds aan de ATEX-richtlijn. Deze verklaring is ook geldig als de markering en de certificaten van de vermelde apparaten overeenkomen met vroegere versies van normen.*