

Pepperl+Fuchs SE
Lilienthalstraße 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No.: DOC-1039D
Date / Tarih: 2024-06-12

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com

PEPPERL+FUCHS

Declaration of Conformity / Uygunluk Beyanı

We, Pepperl+Fuchs SE, declare under our sole responsibility that the products listed below are in conformity with the listed European Directives, Regulations, and standards.

Pepperl+Fuchs SE olarak, yegane sorumluluğumuz uyarınca aşağıda yer alan ürünlerin, belirtilen Avrupa Direktifleri, Yönetmelikleri ve standartları ile uyumlu olduğunu beyan ederiz.

Products / Ürünler

Product Ürün	Itemnumber Öge numarası	Description Açıklama
LB3106A	254716	Transmitter Power Supply
LB4101A2	254722	Analog Output
LB4102A2	254723	Analog Output
LB4102C2	254724	Analog Output
LB4104A2	254725	Analog Output
LB4105A2	254726	Analog Output
LB4105C2	254727	Analog Output
LB4106A	254729	Analog Output
LB4106C	254730	Analog Output
LB7104A	254847	Universal Analog I/O
LB7104E	70176490	Universal Analog I/O

Directives and Standards / Direktifler ve Standartlar

EU Directive AB Direktifi	Standards Standartlar
ATEX 2014/34/EU (L96/309-356)	EN 60079-11:2012-01 EN IEC 60079-0/AC:2020-02 EN 60079-15:2010-05 EN IEC 60079-0:2018-07
EMC 2014/30/EU (L96/79-106)	EN 61326-1:2013-01
RoHS 2011/65/EU (L174/88-110)	EN IEC 63000:2018-12

Affixed CE Marking / Ekli CE İşareti

CE 0102

ppa. Michael Kessler i.V. Norbert Lindner

Executive Vice President
Components & Technology

Continuation Manager Value Engineering

The English version represents the signed original.
İngilizce sürüm, imzalanan orijinali temsil eder.

ANNEX ATEX / ATEX EKI

Notified Body QM System / Onaylı Kuruluş Kalite Yönetim Sistemi

Physikalisch Technische Bundesanstalt (0102)
Bundesallee 100
38116 Braunschweig
Germany

Marking and Certificates / İşaret ve Sertifikalar

Marking İşaret	Certificate Sertifika	ID Kimlik
⊕ I (M1) ⊕ II (1) D ⊕ II 3 (1) G	BVS 11 ATEX E 116 X	0158

Key for ID / Kimlik Anahtarı

ID Kimlik	Responsible Body Sorumlu Kuruluş
0158	DEKRA Testing and Certification GmbH Handwerkstraße 15 70565 Stuttgart Germany

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the Essential Health and Safety Requirements. The products still comply with the ATEX Directive. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.

Pepperl+Fuchs SE, standartların yeni sürümüyle ilgili olarak, ürünlerin yalnızca küçük veya resmi değişikliklerden etkilendiğini beyan eder. Bu değişiklikler, temel sağlık ve güvenlik gerekliliklerine uygunlukla ilgili değildir. Ürünler hala ATEX Direktifi ile uyumludur. Ayrıca belirtilen cihazlara ait işaret ve sertifikalar, standartların önceki sürümleriyle uyumlu olduğunda da bu beyan geçerlidir.