

Pepperl+Fuchs SE
Lilienthalstraße 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No. / Št.: **DOC-1057D**
Date / Datum: **2023-09-19**

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com

 **PEPPERL+FUCHS**

Declaration of conformity / Izjava o skladnosti

We Pepperl+Fuchs SE declare under our sole responsibility that the products listed below are in conformity with the listed European Directives and standards.

Družba Pepperl+Fuchs SE na lastno odgovornost izjavlja, da so spodaj navedeni proizvodi v skladu z navedenimi evropskimi direktivami in standardi.

Products / Proizvodi

| Products Proizvodi | Itemnumber Št. izdelka | Description Opis |
|-----------------------|---------------------------|---------------------|
| FB6210BR | 276336 | Digital Output |
| FB6210ER | 276337 | Digital Output |
| FB6211BR | 276338 | Digital Output |
| FB6211ER | 276339 | Digital Output |
| FB6213BR | 276340 | Digital Output |
| FB6215BR | 276342 | Digital Output |

Directives and Standards / Direktive in standardi

| EU-Directive Direktive EU | Standards Standardi |
|----------------------------------|---|
| ATEX 2014/34/EU (L96/309-356) | EN 60079-1:2014-10 EN 60079-26:2015-01 EN 60079-11:2012-01 EN IEC 60079-0:2018-07 EN IEC 60079-0/AC:2020-02 |
| EMC 2014/30/EU (L96/79-106) | EN 61326-1:2013-01 |
| RoHS 2011/65/EU (L174/88-110) | EN IEC 63000:2018-12 |

Affixed CE Marking / Pritrjena oznaka CE

 0102

Signatures / Podpisi

Mannheim, 2023-09-19

 

ppa. Michael Kessler
Executive Vice President
Components & Technology

i.V. Norbert Lindner
Continuation Manager Value Engineering

The English version represents the signed original.
Angleška različica predstavlja podpisan izvirnik.

ANNEX ATEX / PRILOGA ATEX

Notified Body QM-System / Priglašen organ sistema vodenja kakovosti

Physikalisch Technische Bundesanstalt (0102)
Bundesallee 100
38116 Braunschweig
Germany

Marking and Certificates / Oznaka in potrdila

| Marking Oznaka | Certificate Potrdilo | Issuer ID ID izdajatelja |
|--|-------------------------|-----------------------------|
| ⊕ II (1) D ⊕ II 2 (1) G ⊕ II 2 G | PTB 97 ATEX 1074U | 0102 |

Key for Issuer ID / Ključ za ID izdajatelja

| ID | Issuer Izdajatelj |
|------|---|
| 0102 | Physikalisch Technische Bundesanstalt Bundesallee 100 38116 Braunschweig Germany |

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the essential health and safety requirements. The products still comply with the ATEX Directive. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.

Družba Pepperl+Fuchs SE izjavlja, da na proizvode vplivajo samo manjše ali formalne spremembe glede nove izdaje standardov. Te spremembe ne vplivajo na skladnost z bistvenimi zdravstvenimi in varnostnimi zahtevami. Proizvodi so še vedno v skladu z direktivo ATEX. Ta izjava je veljavna tudi, če oznaka in potrdila navedenih naprav ustrezajo prejšnjim izdajam standardov.