

The products listed above fulfill the immunity test requirements for equipment intended for use in industrial locations.
Ovennævnte produkter opfylder kravene til immunitet for udstyr beregnet til brug i industrielle omgivelser.

Pepperl+Fuchs SE
Lilienthalstraße 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No. /Nr.: **DOC-3878B**
Date /Dato: **2023-10-19**

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com



■ Declaration of conformity / Overensstemmelseserklæring

We Pepperl+Fuchs SE declare under our sole responsibility that the products listed below are in conformity with the listed European Directives and standards.

Vi, Pepperl+Fuchs SE, erklærer hermed under eneansvar, at de nedenfor anførte produkter er i overensstemmelse med de angivne EU-direktiver og -standarder.

■ Products / Produkter

Products Produkter	Itemnumber Varenummer	Description Beskrivelse
KFD2-RSH-1.2D.FL3	274894	Relay Module
KFD2-RSH-1.2D.FL3-Y1	326596	Relay Module

■ Directives and Standards / Direktiver og standarder



EU-Directive EU-direktiv	Standards Standarder
EMC 2014/30/EU (L96/79-106)	EN 61326-1:2013-01
LVD 2014/35/EU (L96/357-374)	EN 61010-1:2010-10
MD 2006/42/EC (L157/24-86)	EN ISO 13849-1:2015-12 EN IEC 62061:2021-07
RoHS 2011/65/EU (L174/88-110)	EN IEC 63000:2018-12

■ Affixed CE Marking / Anbragt CE-mærkning



■ Signatures / Underskrifter

Mannheim, 2023-10-19

ppa.  
ppa. Michael Kessler i.V. Udo Körner
Executive Vice President Continuation Manager Value Engineering
Components & Technology

The English version represents the signed original.
Den engelske version repræsenterer den underskrevne original.