

Pepperl+Fuchs SE
Lilienthalstraße 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No. / Nr.: **DOC-4262D**
Date / Datum: **2024-06-12**

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com



Declaration of Conformity / Försäkran om överensstämmelse

We, Pepperl+Fuchs SE, declare under our sole responsibility that the products listed below are in conformity with the listed European Directives, Regulations, and standards.

Vi, Pepperl+Fuchs SE, försäkrar under ensamt ansvar att produkterna som anges nedan överensstämmer med angivna EU-direktiv, -bestämmelser och -standarder.

Products / Produkter

Product Produkt	Itemnumber Artikelnummer	Description Beskrivning
FB4202B3	276322	Analog Output
FB4205B3	276325	Remote I/O - FB
FB7204B3	223085	Universal Analog I/O
FB7204E3	70176502	Universal Analog I/O

Directives and Standards / Direktiv och standarder

EU Directive EU-direktiv	Standards Standarder
ATEX 2014/34/EU (L96/309-356)	EN IEC 60079-0/AC:2020-02 EN IEC 60079-0:2018-07 EN 60079-1:2014-10 EN 60079-11:2012-01 EN 60079-5:2015-04 EN 60079-7:2015-12 EN IEC 60079-7/A1:2018-01
EMC 2014/30/EU (L96/79-106)	EN 61326-1:2013-01
RoHS 2011/65/EU (L174/88-110)	EN IEC 63000:2018-12

Affixed CE Marking / Fäst CE-märkning



0102

ppa. Michael Kessler i.V. Norbert Lindner

Executive Vice President
Components & Technology

Continuation Manager Value Engineering

The English version represents the signed original.
Den engelska versionen utgör det undertecknade originalet.

ANNEX ATEX / ATEX-BILAGA

Notified Body QM System / Anmält organ, kvalitetsledningssystem

Physikalisch Technische Bundesanstalt (0102)
Bundesallee 100
38116 Braunschweig
Germany

Marking and Certificates / Märkning och certifikat

Marking Märkning	Certificate Certifikat:	ID
⊕ I (M1) ⊕ II (1) D ⊕ II 2 (1) G	Presafe 19 ATEX 14057U	2460

Key for ID / Nyckel för ID

ID	Responsible Body Ansvarigt organ
2460	DNV GL Presafe AS Veritasveien 3 1363 Høvik Norway

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the Essential Health and Safety Requirements. The products still comply with the ATEX Directive. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.

Pepperl+Fuchs SE försäkrar att produkterna endast påverkas av mindre eller formella ändringar när det gäller den nya utgåvan av standarderna. Dessa ändringar är inte relevanta för överensstämmelsen med de grundläggande hälso- och säkerhetskraven. Produkterna överensstämmer fortfarande med ATEX-direktivet. Denna försäkran gäller även om märkningen och certifikaten för ovan nämnda enheter motsvarar tidigare utgåvors standarder.