

Pepperl+Fuchs SE  
Lilienthalstraße 200  
68307 Mannheim  
Germany  
Phone +49 621 776-0  
Fax +49 621 776-1000

No. / Št.: **DOC-4286C**  
Date / Datum: **2023-05-02**

Copyright Pepperl+Fuchs  
www.pepperl-fuchs.com



### Declaration of conformity / Izjava o skladnosti

We Pepperl+Fuchs SE declare under our sole responsibility that the products listed below are in conformity with the listed European Directives and standards.

*Družba Pepperl+Fuchs SE na lastno odgovornost izjavlja, da so spodaj navedeni proizvodi v skladu z navedenimi evropskimi direktivami in standardi.*

### Products / Proizvodi

Products Proizvodi	Itemnumber Št. izdelka	Description Opis
M-LB-2112	313279	Surge protection barrier
M-LB-2112.SP	313287	Surge protection barrier
M-LB-2114	313280	Surge protection barrier
M-LB-2114.SP	313288	Surge protection barrier
M-LB-2142	313281	Surge protection barrier
M-LB-2142.SP	313289	Surge protection barrier
M-LB-2144	313282	Surge Protection Barrier
M-LB-2144.SP	313290	Surge protection barrier

### Directives and Standards / Direktive in standardi

EU-Directive Direktive EU	Standards Standardi
ATEX 2014/34/EU (L96/309-356)	EN IEC 60079-7/A1:2018-01 EN 60079-7:2015-12 EN IEC 60079-0:2018-07 EN IEC 60079-0/AC:2020-02
RoHS 2011/65/EU (L174/88-110)	EN IEC 63000:2018-12

### Affixed CE Marking / Pritrjena oznaka CE



*ppa. M. Michael Kessler*

ppa. Michael Kessler  
Executive Vice President  
Components & Technology

*i.V. Martin Holdefer*  
Continuation Manager Value Engineering

The English version represents the signed original.  
*Angleška različica predstavlja podpisan izvirnik.*

### ANNEX ATEX / PRILOGA ATEX

#### Marking and Certificates / Oznaka in potrdila

Marking Oznaka	Certificate Potrdilo	Issuer ID ID izdajatelja
Ⓔ II 3 G	KIWA 19 ATEX 0002 X	SIR

#### Key for Issuer ID / Ključ za ID izdajatelja

ID	Issuer Izdajatelj
SIR	CSA Group Netherlands B.V Utrechtseweg 310 6812 AR Arnhem Netherlands