

Pepperl+Fuchs SE
Lilienthalstraße 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No. / Br.: **DOC-4840B**
Date / Datum: **2023-10-20**

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com



Declaration of conformity / Deklaracija o sukladnosti

We Pepperl+Fuchs SE declare under our sole responsibility that the products listed below are in conformity with the listed European Directives and standards.

Mi, Pepperl+Fuchs SE, izjavljujemo pod vlastitom i isključivom odgovornošću da su proizvodi u nastavku sukladni navedenim europskim direktivama i standardima.

Products / Proizvodi

| Products Proizvodi | Itemnumber Broj stavke | Description Opis |
|-------------------------|---------------------------|---------------------|
| HICTB16-TRX-RAC-PL-AI16 | 70127424 | Termination Board |
| HICTB16-TRX-RAC-PL-DI16 | 70127425 | Termination Board |
| HICTB16-TRX-RAC-PL-DI32 | 70127426 | Termination Board |
| HICTB16-TRX-RAC-PL-DO16 | 70127427 | Termination Board |
| HICTB16-TRX-RAC-PL-IO16 | 70132824 | Termination Board |
| HICTB16-TRX-RAS-PL-AI16 | 70159655 | Termination Board |
| HICTB16-TRX-RAS-PL-IO16 | 70146723 | Termination Board |

Directives and Standards / Direktive i standardi

| EU-Directive EU direktiva | Standards Standardi |
|----------------------------------|--|
| ATEX 2014/34/EU (L96/309-356) | EN 60079-11:2012-01 EN 50303:2000-07 EN IEC 60079-0:2018-07 EN IEC 60079-0/AC:2020-02 |
| EMC 2014/30/EU (L96/79-106) | EN 61326-1:2013-01 |
| RoHS 2011/65/EU (L174/88-110) | EN IEC 63000:2018-12 |

Affixed CE Marking / Dodijeljena CE oznaka



Signatures / Potpisi

Mannheim, 2023-10-20

ppa. Michael Kessler i.V. Maren Klotz

Executive Vice President
Components & Technology

Continuation Manager Value Engineering

The English version represents the signed original.
Verzija na engleskom jeziku predstavlja potpisani originalni dokument.

ANNEX EMC / ANEKS EMC

The products listed above fulfill the immunity test requirements for equipment intended for use in industrial locations.
Proizvodi navedeni iznad ispunjavaju zahtjeve testova otpornosti za opremu namijenjenu uporabi na industrijskim lokacijama.

ANNEX ATEX / ANEKS ATEX

Notified Body QM-System / Prijavljeno tijelo QM-System

Physikalisch Technische Bundesanstalt (0102)
Bundesallee 100
38116 Braunschweig
Germany

Marking and Certificates / Označavanje i certifikati

| Marking Označavanje | Certificate Certifikat | Issuer ID ID izdavača |
|--------------------------------------|---------------------------|--------------------------|
| ⊕ I (M1) ⊕ II (1) D ⊕ II (1) G | CESI 06 ATEX 022 | 0722 |

Key for Issuer ID / Šifra za ID izdavača

| ID | Issuer Izdavač |
|------|--|
| 0722 | CESI Via Rubattino 54 20134 Milan Italy |

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the essential health and safety requirements. The products still comply with the ATEX Directive. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.
Pepperl+Fuchs SE izjavljuje da su proizvodi zahvaćeni samo malim ili formalnim promjenama u odnosu na novo izdanje standarda. Te promjene nisu relevantne za usklađenost s ključnim zahtjevima o zdravlju i sigurnosti. Proizvodi su i dalje sukladni direktivi ATEX. Ova je izjava također važeća ako oznake i certifikati navedenih uređaja odgovaraju prethodnim izdanjima standarda.