

Pepperl+Fuchs SE  
Lilienthalstraße 200  
68307 Mannheim  
Germany  
Phone +49 621 776-0  
Fax +49 621 776-1000

No. / Č.: **DOC-5037B**  
Date / Dátum: **2023-03-03**

Copyright Pepperl+Fuchs  
[www.pepperl-fuchs.com](http://www.pepperl-fuchs.com)



### Declaration of conformity / Vyhlásenie o zhode

We Pepperl+Fuchs SE declare under our sole responsibility that the products listed below are in conformity with the listed European Directives and standards.

My, spoločnosť Pepperl+Fuchs SE, vyhlasujeme na našu výhradnú zodpovednosť, že produkty uvedené nižšie sú v súlade s uvedenými európskymi smernicami a normami.

### Products / Produkty

Products Produkty	Itemnumber Číslo položky	Description Opis
FB1308B3	276221	Digital Input

### Directives and Standards / Smernice a normy


EU-Directive Smernice EU	Standards Normy
ATEX 2014/34/EU (L96/309-356)	EN 60079-7:2015-12 EN 60079-1:2014-10 EN 60079-5:2015-04 EN IEC 60079-0:2018-07 EN IEC 60079-7/A1:2018-01 EN IEC 60079-0/AC:2020-02
EMC 2014/30/EU (L96/79-106)	EN 61326-1:2013-01
RoHS 2011/65/EU (L174/88-110)	EN IEC 63000:2018-12


### Affixed CE Marking / Priložené označenie CE



### Signatures / Podpisy

Mannheim, 2023-03-03

  
 ppa. Michael Kessler  
 Executive Vice President  
 Components & Technology

  
 i.V. Norbert Lindner  
 Continuation Manager Value Engineering

The English version represents the signed original.  
Podpísaný originál dokumentu je v anglickej verzii.

### ANNEX ATEX / PRÍLOHA ATEX

Notified Body QM-System / Notifikovaný orgán – Systém manažérstva kvality (QM-System)

Physikalisch Technische Bundesanstalt (0102)  
Bundesallee 100  
38116 Braunschweig  
Germany

### Marking and Certificates / Označenia a certifikáty

Marking Označenie	Certificate Certifikát	Issuer ID Emitent ID
⊕ II 2 G	FIDI 21 ATEX 0012U	2829

### Key for Issuer ID / Kľúč emitenta ID

ID	Issuer Emitent
2829	Fiditas d.o.o. Karlovačka cesta 197 10250 Zagreb-Lučko Croatia

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the essential health and safety requirements. The products still comply with the ATEX Directive. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.

Spoločnosť Pepperl+Fuchs SE vyhlasuje, že na produktoch sa vykonali iba menšie alebo formálne úpravy vzhľadom na nové vydanie noriem.

Tieto úpravy nie sú relevantné pre súlad s požiadavkami na ochranu zdravia a bezpečnosti. Tieto produkty sú stále v súlade so smernicou ATEX. Toto vyhlásenie je platné aj vtedy, ak označenie a certifikáty uvedených zariadení zodpovedajú predchádzajúcim vydaniám noriem.