

Pepperl+Fuchs SE
Lilienthalstraße 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No. /Nr.: **DOC-5038C**
Date /Dato: **2024-06-12**

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com



Declaration of Conformity / Overensstemmelseserklæring

We, Pepperl+Fuchs SE, declare under our sole responsibility that the products listed below are in conformity with the listed European Directives, Regulations, and standards.
Vi, Pepperl+Fuchs SE, erklærer hermed under eneansvar, at de nedenfor anførte produkter er i overensstemmelse med de angivne EU-direktiver og -standarder.

Products / Produkter

Product Produkt	Itemnumber Varenummer	Description Beskrivelse
FB7304B3	239065	Universal Analog I/O
FB7304E3	70176505	Universal Analog I/O

Directives and Standards / Direktiver og standarder



EU Directive EU-direktiv	Standards Standarder
ATEX 2014/34/EU (L96/309-356)	EN IEC 60079-0:2018-07 EN 60079-7:2015-12 EN 60079-1:2014-10 EN 60079-5:2015-04 EN IEC 60079-0/AC:2020-02 EN IEC 60079-7/A1:2018-01
EMC 2014/30/EU (L96/79-106)	EN 61326-1:2013-01
RoHS 2011/65/EU (L174/88-110)	EN IEC 63000:2018-12

Affixed CE Marking / Anbragt CE-mærkning



Signatures / Underskrifter

Mannheim, 2024-06-12

ppa.  i.V. 
ppa. Michael Kessler i.V. Norbert Lindner
Executive Vice President Continuation Manager Value Engineering
Components & Technology

The English version represents the signed original.
Den engelske version repræsenterer den underskrevne original.

ANNEX ATEX / ATEX-BILAG

Notified Body QM System / Bemyndiget organ, kvalitetsstyrings-system

Physikalisch Technische Bundesanstalt (0102)
Bundesallee 100
38116 Braunschweig
Germany

Marking and Certificates / Mærkning og certifikater

Marking Mærkning	Certificate Certifikat	ID
⊕ II 2 G	FIDI 21 ATEX 0013U	2829

Key for ID / ID-nøgle

ID	Responsible Body Ansvarligt organ
2829	Fiditas d.o.o. Slavka Tomerlina 44 10361 Zagreb-Sesvete Croatia

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the Essential Health and Safety Requirements. The products still comply with the ATEX Directive. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.

Pepperl+Fuchs SE erklærer hermed, at produkterne kun udsættes for mindre eller formelle ændringer i henhold til opdaterede udgaver af standarderne. Disse ændringer påvirker ikke overholdelsen af de væsentlige sikkerheds- og sundhedskrav. Produkterne er stadig i overensstemmelse med ATEX-direktivet. Denne erklæring er også gældende, hvis mærkning og certifikater for de anførte enheder svarer til tidligere udgaver af standarderne.