

Pepperl+Fuchs SE
Lilienthalstraße 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No. / Br.: **DOC-5252C**
Date / Datum: **2023-05-24**

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com



Declaration of conformity / Deklaracija o sukladnosti

We Pepperl+Fuchs SE declare under our sole responsibility that the products listed below are in conformity with the listed European Directives and standards.

Mi, Pepperl+Fuchs SE, izjavljujemo pod vlastitom i isključivom odgovornošću da su proizvodi u nastavku sukladni navedenim europskim direktivama i standardima.

Products / Proizvodi

| Products Proizvodi | Itemnumber Broj stavke | Description Opis |
|-----------------------|---------------------------|---------------------|
| KCD2-SR-EX1 | 70109406 | Switch amplifier |
| KCD2-SR-EX1.LB | 70112151 | Switch amplifier |
| KCD2-SR-EX1.LB-AB | 70112154 | Switch amplifier |
| KCD2-SR-EX1.LB.SP | 70112156 | Switch amplifier |
| KCD2-SR-EX2 | 70112153 | Switch amplifier |
| KCD2-SR-EX2-AB | 70112155 | Switch amplifier |
| KCD2-SR-EX2.SP | 70112160 | Switch amplifier |

Directives and Standards / Direktive i standardi

| EU-Directive EU direktiva | Standards Standardi |
|----------------------------------|--|
| ATEX 2014/34/EU (L96/309-356) | EN IEC 60079-0:2018-07 EN 60079-7:2015-12 EN 60079-11:2012-01 EN IEC 60079-7/A1:2018-01 EN IEC 60079-15:2019-04 EN IEC 60079-0/AC:2020-02 |
| EMC 2014/30/EU (L96/79-106) | EN 61326-1:2013-01 |
| RoHS 2011/65/EU (L174/88-110) | EN IEC 63000:2018-12 |
| Supplemental Standards | EN 61010-1/A1:2019-02 EN 61010-1:2010-10 EN 61010-1/A1/AC:2019-04 |

Affixed CE Marking / Dodijeljena CE oznaka



ppa. Michael Kessler
Executive Vice President
Components & Technology

i.V. Udo Körner
Continuation Manager Value Engineering

The English version represents the signed original.
Verzija na engleskom jeziku predstavlja potpisani originalni dokument.

ANNEX EMC / ANEKS EMC

The products listed above fulfill the immunity test requirements for equipment intended for use in industrial locations.
Proizvodi navedeni iznad ispunjavaju zahtjeve testova otpornosti za opremu namijenjenu uporabi na industrijskim lokacijama.

ANNEX ATEX / ANEKS ATEX

Notified Body QM-System / Prijavljeno tijelo QM-System

Physikalisch Technische Bundesanstalt (0102)
Bundesallee 100
38116 Braunschweig
Germany

Marking and Certificates / Označavanje i certifikati

| Marking Označavanje | Certificate Certifikat | Issuer ID ID izdavača |
|--|---------------------------|--------------------------|
| ⊕ I (M1) ⊕ II (1) D ⊕ II 3 (1) G | Baseefa 06 ATEX 0092X | 0598 |

Key for Issuer ID / Šifra za ID izdavača

| ID | Issuer Izdavač |
|------|--|
| 0598 | SGS FIMKO OY Takomotie 8 00380 Helsinki Finland |