

Pepperl+Fuchs SE
Lilienthalstraße 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No. / N.º: **DOC-5252C**
Date / Data: **2023-05-24**

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com



Declaration of conformity / Declaração de conformidade

We Pepperl+Fuchs SE declare under our sole responsibility that the products listed below are in conformity with the listed European Directives and standards.

A Pepperl+Fuchs SE declara, sob sua inteira responsabilidade, que os produtos abaixo indicados estão em conformidade com as normativas e diretivas europeias indicadas.

Products / Produtos

Products Produtos	Itemnumber Número de item	Description Descrição
KCD2-SR-EX1	70109406	Switch amplifier
KCD2-SR-EX1.LB	70112151	Switch amplifier
KCD2-SR-EX1.LB-AB	70112154	Switch amplifier
KCD2-SR-EX1.LB.SP	70112156	Switch amplifier
KCD2-SR-EX2	70112153	Switch amplifier
KCD2-SR-EX2-AB	70112155	Switch amplifier
KCD2-SR-EX2.SP	70112160	Switch amplifier

Directives and Standards / Diretivas e normativas

EU-Directive Diretiva da UE	Standards Normativas
ATEX 2014/34/EU (L96/309-356)	EN IEC 60079-0:2018-07 EN 60079-7:2015-12 EN 60079-11:2012-01 EN IEC 60079-7/A1:2018-01 EN IEC 60079-15:2019-04 EN IEC 60079-0/AC:2020-02
EMC 2014/30/EU (L96/79-106)	EN 61326-1:2013-01
RoHS 2011/65/EU (L174/88-110)	EN IEC 63000:2018-12
Supplemental Standards	EN 61010-1/A1:2019-02 EN 61010-1:2010-10 EN 61010-1/A1/AC:2019-04

Affixed CE Marking / Marcação CE anexada



0102

ppa. Michael Kessler
Executive Vice President
Components & Technology

i.V. Udo Körner
Continuation Manager Value Engineering

The English version represents the signed original.
A versão em inglês representa o documento original assinado.

ANNEX EMC / ANEXO EMC

The products listed above fulfill the immunity test requirements for equipment intended for use in industrial locations.
Os produtos acima indicados cumprem os requisitos de teste de imunidade para equipamento destinado a ser utilizado em localizações industriais.

ANNEX ATEX / ANEXO ATEX

Notified Body QM-System / Sistema QM do organismo notificado

Physikalisch Technische Bundesanstalt (0102)
Bundesallee 100
38116 Braunschweig
Germany

Marking and Certificates / Marcação e certificados

Marking Marcação	Certificate Certificado	Issuer ID ID da entidade emissora
⊕ I (M1) ⊕ II (1) D ⊕ II 3 (1) G	Baseefa 06 ATEX 0092X	0598

Key for Issuer ID / Chave para ID da entidade emissora

ID	Issuer Entidade emissora
0598	SGS FIMKO OY Takomotie 8 00380 Helsinki Finland