

Pepperl+Fuchs SE
 Lilienthalstraße 200
 68307 Mannheim
 Germany
 Phone +49 621 776-0
 Fax +49 621 776-1000

No.: DOC-5371A
 Date: 2024-06-12

Copyright Pepperl+Fuchs
 www.pepperl-fuchs.com



Declaration of Conformity

We, Pepperl+Fuchs SE, declare under our sole responsibility that the products listed below are in conformity with the below listed UK Regulations (as amended) and standards.

Products

| Product | Itemnumber | Description |
|----------|------------|--------------------------|
| LB3106A | 254716 | Transmitter Power Supply |
| LB4101A2 | 254722 | Analog Output |
| LB4102A2 | 254723 | Analog Output |
| LB4102C2 | 254724 | Analog Output |
| LB4104A2 | 254725 | Analog Output |
| LB4105A2 | 254726 | Analog Output |
| LB4105C2 | 254727 | Analog Output |
| LB4106A | 254729 | Analog Output |
| LB4106C | 254730 | Analog Output |
| LB7104A | 254847 | Universal Analog I/O |
| LB7104E | 70176490 | Universal Analog I/O |

Regulations and Standards

| UK Regulation | Standards |
|----------------------------|---|
| UK SI 2012 No. 3032 (RoHS) | EN IEC 63000:2018-12 |
| UK SI 2016 No. 1091 (EMC) | EN 61326-1:2013-01 |
| UK SI 2016 No. 1107 (EX) | EN 60079-11:2012-01 EN IEC 60079-0/AC:2020-02 EN 60079-15:2010-05 EN IEC 60079-0:2018-07 |

Affixed UKCA Marking



Signatures

Mannheim, 2024-06-12

ppa. M. Kessler *i.V. Norbert Lindner*

ppa. Michael Kessler
 Executive Vice President
 Components & Technology

i.V. Norbert Lindner
 Continuation Manager Value Engineering

ANNEX UK SI 2016 No. 1107 (EX)

Approved Body QM System

Eurofins E&E CML Limited (2503)
 Newport Business Park - New Port Road
 CH65 4LZ Ellesmere Port
 United Kingdom

Marking and Certificates

| Marking | Certificate | ID |
|--|-----------------|------|
| Ⓜ I (M1) Ⓜ II (1) D Ⓜ II 3 (1) G | CML 21UKEX2659X | 2503 |

Key for ID

| ID | Responsible Body |
|------|--|
| 2503 | Eurofins E&E CML Limited Newport Business Park - New Port Road CH65 4LZ Ellesmere Port United Kingdom |

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the Essential Health and Safety Requirements. The products still comply with UK SI 2016 No. 1107. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.