

Pepperl+Fuchs SE
Lilienthalstrasse 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No: DOC-6551A
Date: 2022-09-22

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com



Declaration of conformity

We, Pepperl+Fuchs SE declare under our sole responsibility that the **products** listed below are in conformity with the listed **UK Regulations** as indicated below and amended by **UK SI 2019 No. 696**, and **standards**.

Products

Product	Item number	Description
NCB20-L2-N0-V1	70133147	Inductive sensor
NCN40-L2-N0-V1	70133101	Inductive sensor

Regulations and Standards

UK Regulation	Standards
UK SI 2012 No. 3032 (RoHS)	EN IEC 63000:2018-12
UK SI 2016 No. 1091 (EMC)	EN 60947-5-6:2000-01 EN IEC 60947-5-2:2020-03
UK SI 2016 No. 1107 (EX)	EN 60079-11:2012-01 EN 60079-31:2014-07 EN IEC 60079-0:2018-07

Affixed UKCA Marking



Signatures

Mannheim, 2022-09-22

i.V. Ulrich Ehrenfried
Head of Innovation Unit
Electromagnetic Sensors

i.V. Mark Guenther
Global Product Manager

ANNEX UK SI 2016 No. 1107 (EX)

Approved Body QM-System:

Eurofins E&E CML Limited (2503)
Newport Business Park - New Port Road
CH65 4LZ Ellesmere Port
United Kingdom

Marking and Certificates

Marking	Certificate	ID
 	CML 21UKEX2975X	2503
	TÜV 20 ATEX 8526 X	TUR

Key for ID

ID	Responsible Body
2503	Eurofins E&E CML Limited Newport Business Park - New Port Road CH65 4LZ Ellesmere Port United Kingdom
TUR	TÜV Rheinland Industrial Services GmbH Automation and Functional Safety (AFS) Am Grauen Stein 51105 Cologne Germany