

Pepperl+Fuchs SE
Lilienthalstraße 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No.: DOC-6611B
Date / Tarih: 2024-03-22

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com

PEPPERL+FUCHS

Declaration of Conformity / Uygunluk Beyanı

We, Pepperl+Fuchs SE, declare under our sole responsibility that the products listed below are in conformity with the listed European Directives, Regulations, and standards.

Pepperl+Fuchs SE olarak, yegane sorumluluğumuz uyarınca aşağıda yer alan ürünlerin, belirtilen Avrupa Direktifleri, Yönetmelikleri ve standartları ile uyumlu olduğunu beyan ederiz.

Products / Ürünler

Product Ürün	Itemnumber Öge numarası	Description Açıklama
KFD2-SLD-EX2.1045	70153575	Solenoid driver
KFD2-SLD-EX2.1045-Y1	70178494	Solenoid driver
KFD2-SLD-EX2.1245	70153576	Solenoid driver
KFD2-SLD-EX2.1245-Y1	70178495	Solenoid driver
KFD2-SLD-EX2.1545	70153577	Solenoid driver
KFD2-SLD-EX2.1545-Y1	70178496	Solenoid driver
KFD0-SD2-EX2.1045	70105780	Solenoid driver
KFD0-SD2-EX2.1245	70105779	Solenoid driver
KFD0-SD2-EX2.1545	70105778	Solenoid driver

Directives and Standards / Direktifler ve Standartlar

EU Directive AB Direktifi	Standards Standartlar
ATEX 2014/34/EU (L96/309-356)	EN 60079-7:2015-12 EN IEC 60079-7/A1:2018-01 EN IEC 60079-0:2018-07 EN 60079-11:2012-01 EN IEC 60079-0/AC:2020-02
EMC 2014/30/EU (L96/79-106)	EN 61326-1:2013-01
RoHS 2011/65/EU (L174/88-110)	EN IEC 63000:2018-12

Affixed CE Marking / Ekli CE İşareti

CE 0102

ppa. Michael Kessler i.V. S. Pflüger

ppa. Michael Kessler
Executive Vice President
Components & Technology

i.V. Stefan Pflüger
Product Portfolio Manager Interface
Technology

The English version represents the signed original.
İngilizce sürüm, imzalanan orijinali temsil eder.

ANNEX EMC / EMC EKİ

The products listed above fulfill the immunity test requirements for equipment intended for use in industrial locations.
Yukarıda yer alan ürünler, endüstriyel alanlarda kullanım amaçlı ekipmanlar için bağışıklık testi gerekliliklerini yerine getirmektedir.

ANNEX ATEX / ATEX EKİ

Notified Body QM System / Onaylı Kuruluş Kalite Yönetim Sistemi

Physikalisch Technische Bundesanstalt (0102)
Bundesallee 100
38116 Braunschweig
Germany

Marking and Certificates / İşaret ve Sertifikalar

Marking İşaret	Certificate Sertifika	ID Kimlik
⊕ I (M1) ⊕ II (1) D ⊕ II 3 (1) G	FIDI 21 ATEX 0091X	2829

Key for ID / Kimlik Anahtarı

ID Kimlik	Responsible Body Sorumlu Kuruluş
2829	Fiditas d.o.o. Slavka Tomerlina 44 10361 Zagreb-Sesvete Croatia

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the Essential Health and Safety Requirements. The products still comply with the ATEX Directive. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.

Pepperl+Fuchs SE, standartların yeni sürümüyle ilgili olarak, ürünlerin yalnızca küçük veya resmi değişikliklerden etkilendiğini beyan eder. Bu değişiklikler, temel sağlık ve güvenlik gerekliliklerine uygunlukla ilgili değildir. Ürünler hala ATEX Direktifi ile uyumludur. Ayrıca belirtilen cihazlara ait işaret ve sertifikalar, standartların önceki sürümleriyle uyumlu olduğunda da bu beyan geçerlidir.