

Pepperl+Fuchs SE  
 Lilienthalstraße 200  
 68307 Mannheim  
 Germany  
 Phone +49 621 776-0  
 Fax +49 621 776-1000

**No.: DOC-7080A**  
**Date: 2024-11-05**

Copyright Pepperl+Fuchs SE  
[www.pepperl-fuchs.com](http://www.pepperl-fuchs.com)



**Declaration of Conformity**

We, Pepperl+Fuchs SE, declare under our sole responsibility that the products listed below are in conformity with the below listed UK Regulations (as amended) and standards.

**Products**

Product	Itemnumber	Description
KFD0-CS-EX1.54	70185883	Repeater
KFD0-CS-EX1.54	207802	Repeater
KFD0-CS-EX1.54-Y2	241590	Repeater
KFD0-CS-EX2.54	207804	Repeater
KFD0-CS-EX2.54	70185888	Repeater

**Regulations and Standards**

UK Regulation	Standards
UK SI 2012 No. 3032 (RoHS)	EN IEC 63000:2018-12
UK SI 2016 No. 1091 (EMC)	EN 61326-1:2013-01
UK SI 2016 No. 1107 (EX)	EN 60079-11:2012-01 EN 60079-15:2010-05 EN IEC 60079-0/AC:2020-02 EN IEC 60079-0:2018-07

**Affixed UKCA Marking**



**Signatures**

Mannheim, 2024-11-05

*ppa. Michael Kessler*

ppa. Michael Kessler  
 Executive Vice President  
 Components & Technology

*Udo Körner*

i.V. Udo Körner  
 Continuation Manager Value Engineering

**ANNEX UK SI 2016 No. 1091 (EMC)**

The products listed above fulfill the immunity test requirements for equipment intended for use in industrial locations.

**ANNEX UK SI 2016 No. 1107 (EX)**

**Approved Body QM System**

Eurofins E&E CML Limited (2503)  
 Newport Business Park - New Port Road  
 CH65 4LZ Ellesmere Port  
 United Kingdom

**Marking and Certificates**

Marking	Certificate	ID
⊕ II 3 G	TÜV 99 ATEX 1499X	TUN
⊕ I (M1) ⊕ II (1) D ⊕ II (1) G	BAS21UKEX0426	1180

**Key for ID**

ID	Responsible Body
TUN	TÜV NORD CERT GmbH Am TÜV 1 45307 Essen Germany
1180	SGS Baseefa Limited Rockhead Business Park, Staden Lane SK17 9RZ Buxton; Derbyshire Great Britain

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the Essential Health and Safety Requirements. The products still comply with UK SI 2016 No. 1107. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.