

Pepperl+Fuchs SE
 Lilienthalstraße 200
 68307 Mannheim
 Germany
 Phone +49 621 776-0
 Fax +49 621 776-1000

No.: DOC-7081A
Date: 2024-05-21

Copyright Pepperl+Fuchs
 www.pepperl-fuchs.com



Declaration of Conformity

We, Pepperl+Fuchs SE, declare under our sole responsibility that the products listed below are in conformity with the below listed UK Regulations (as amended) and standards.

Products

Product	Itemnumber	Description
KFD2-PT2-EX1	072018	Signal converter
KFD2-PT2-EX1	70177748	Signal converter
KFD2-PT2-EX1-1	70177760	Signal converter
KFD2-PT2-EX1-1	072019	Signal converter
KFD2-PT2-EX1-5	072023	Signal converter
KFD2-PT2-EX1-5	70177763	Signal converter

Regulations and Standards

UK Regulation	Standards
UK SI 2012 No. 3032 (RoHS)	EN IEC 63000:2018-12
UK SI 2016 No. 1091 (EMC)	EN 61326-1:2013-01
UK SI 2016 No. 1107 (EX)	EN IEC 60079-0:2018-07 EN 60079-11:2012-01 EN 60079-15:2010-05 EN IEC 60079-0/AC:2020-02

Affixed UKCA Marking



Signatures

Mannheim, 2024-05-21

ppa. Michael Kessler

ppa. Michael Kessler
 Executive Vice President
 Components & Technology

Udo Körner

i.V. Udo Körner
 Continuation Manager Value Engineering

ANNEX UK SI 2016 No. 1091 (EMC)

The products listed above fulfill the immunity test requirements for equipment intended for use in industrial locations.

ANNEX UK SI 2016 No. 1107 (EX)

Approved Body QM System

Eurofins E&E CML Limited (2503)
 Newport Business Park - New Port Road
 CH65 4LZ Ellesmere Port
 United Kingdom

Marking and Certificates

Marking	Certificate	ID
Ⓜ II 3 G	TÜV 02 ATEX 1797X	TUN
Ⓜ I (M1) Ⓜ II (1) D Ⓜ II (1) G	BAS21UKEX0427	1180

Key for ID

ID	Responsible Body
1180	SGS Baseefa Limited Rockhead Business Park, Staden Lane SK17 9RZ Buxton; Derbyshire Great Britain
TUN	TÜV NORD CERT GmbH Am TÜV 1 45307 Essen Germany

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the Essential Health and Safety Requirements. The products still comply with UK SI 2016 No. 1107. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.