

Pepperl+Fuchs SE  
Lilienthalstraße 200  
68307 Mannheim  
Germany  
Phone +49 621 776-0  
Fax +49 621 776-1000

No.: DOC-7489  
Date: 2023-10-25

Copyright Pepperl+Fuchs  
www.pepperl-fuchs.com



### Declaration of conformity

We, Pepperl+Fuchs SE declare under our sole responsibility that the products listed below are in conformity with the listed UK Regulations as indicated below and amended by UK SI 2019 No. 696, and standards.

### Products

Products	Itemnumber	Description
KCD2-SCD-EX1.SP	70150941	Current driver
KCD2-STC-EX1	70150439	Transmitter power supply
KCD2-STC-EX1-AB	70150944	Transmitter power supply
KCD2-STC-EX1.SP	70150939	Transmitter power supply
KCD2-SCD-EX1	70150440	Current driver
KCD2-SCD-EX1-AB	70150945	Current driver

### Regulations and Standards

UK Regulation	Standards
UK SI 2012 No. 3032 (RoHS)	EN IEC 63000:2018-12
UK SI 2016 No. 1091 (EMC)	EN 61326-1:2013-01
UK SI 2016 No. 1107 (EX)	EN 60079-11:2012-01 EN 60079-7:2015-12 EN IEC 60079-0:2018-07 EN IEC 60079-7/A1:2018-01 EN IEC 60079-0/AC:2020-02

### Affixed UKCA Marking



### Signatures

Mannheim, 2023-10-25

ppa. Michael Kessler i.V. Stefan Pflüger

ppa. Michael Kessler  
Executive Vice President  
Components & Technology

i.V. Stefan Pflüger  
Product Portfolio Manager Interface  
Technology

### ANNEX UK SI 2016 No. 1091 (EMC)

The products listed above fulfill the immunity test requirements for equipment intended for use in industrial locations.

### ANNEX UK SI 2016 No. 1107 (EX)

#### Approved Body QM-System

Eurofins E&E CML Limited (2503)  
Newport Business Park - New Port Road  
CH65 4LZ Ellesmere Port  
United Kingdom

#### Marking and Certificates

Marking	Certificate	ID
⊕ II 3 G	CESI 19 ATEX 021 X	CES
⊕ I (M1) ⊕ II (1) D ⊕ II (1) G	CML 21UKEX2940X	2503

#### Key for ID

ID	Responsible Body
2503	Eurofins E&E CML Limited Newport Business Park - New Port Road CH65 4LZ Ellesmere Port United Kingdom
CES	CESI Via Rubattino 54 20134 Milan Italy

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the essential health and safety requirements. The products still comply with UK SI 2016 No. 1107. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.