Dimensions





Electrical connection



O = Light on = Dark on

Pinning according

CE

filter

•

٠

.

Features

zone 22

Model Number

RL32-54-Ex2/47/73c

Retroreflective sensor with polarization

with 4-pin, M12 x 1 plastic connector

ATEX-approval for zone 2 and

and conveyor systems

tant glass lens

Sleek design, especially for storage

Excellent optical performance data

Scratch-resistant and solvent resis-

Refer to "General Notes Relating to Pepperl+Fuchs Product Information" Pepperl+Fuchs Group

USA: +1 330 486 0001 www.pepperl-fuchs.com fa-info@us.pepperl-fuchs.com Germany: +49 621 776 4411 fa-info@de.pepperl-fuchs.com

Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com



1

Technical data			
General specifications			
Effective detection range		0 4 m	
Reflector distance		0 4 m	
Threshold detection range		7 m	
Reference target		H60 reflector	
Light type		LED, 660 mm	le red light
Polarization filter		ves	i i cu nghi
Diameter of the light spot		approx. 100 mm	at 4000 mm detection range
Angle of divergence		approx. 3 °	
Ambient light limit		80000 Lux	
Functional safety related parame	ters		
MTTF _d		401 a	
Mission Time (T _M)		20 a	
Diagnostic Coverage (DC)		0 %	
Indicators/operating means			
		LED yellow, light	ts up when light beam is free, flashes when falling short of the stability control
Electrical specifications			
Bipple	υ _B	10 30 V DC	
No-load supply current	lo	40 mA	
Output	•0		
Switching type		light/dark on	
Signal output		2 PNP, complem	nentary, short-circuit protected, reverse polarity protected
Switching voltage		30 V DC	
Switching current		max. 50 mA	
Switching frequency	f	250 Hz	
Response time		2 ms	
Ambient conditions			-
Ambient temperature		-20 50 °C (-4	122 °F)
Storage temperature		-20 60 °C (-4	140 °F)
Protection degree		IP65	
Connection		Plastic connecto	nr M12 x 1 4-nin
Material			
Housing		Terluran GV15	
Optical face		glass	
Mass		60 g	
General information			
Use in the hazardous area		see more details	s for the use in hazardous areas
Category		3G; 3D	
Compliance with standards and over	directi-		
Directive conformity			
EMC Directive 2004/108/EC		EN 60947-5-2:20	007
Standard conformity			007
Product standard		IEC 60947-5-2:20	2007
Approvals and certificates			
CCC approval		CCC approval	/ marking not required for products rated ≤36 V
ATEX 3G (nA)			
Instruction			Manual electrical apparatus for hazardous areas
Device category 3G (nA)			for use in hazardous areas with gas, vapour and mist
ATEX marking			🕼 II 3 G Ex nAc op is IIC T4
Directive conformity			94/9/EG
Standards			EN 60079-0:2009 . EN 60079-15:2010 . EN 60079-28:2007
Installation Comissioning			Laws and/or regulations and standards governing the use or intended usage goal must be observed
			Attach the connector fuse provided so that the connector cannot be unplugged without using tools. Only connections that are disconnected from the power supply may be unplugged.
Maintenance			No modifications must be undertaken on apparatus, which is operated in hazardous areas. Repairs to such apparatus are not permissible.
Specific conditions			
Maximum permissible ambient temperature Turney			50 °C (122 °F)
Protection from mechanical danger		Omax	The apparatus must be protected from mechanical damage.
Protection of overvoltage			Precautions must be taken to prevent the rated voltage being exceeded by more than 40 % due to tran-
			sient disturbances.
Protect from direct sunlight			Set up the apparatus so that optical components cannot come into contact with direct sunlight.
Protection from UV light			The sensor must be protected against harmful UV radiation. This can be achieved by using the sensor indoors.

Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com



The optical light from the emitter must not be focused. The plug connector must not be disconnected under voltage. When the plug connector is disconnected the ingress of dirt into the inner areas (i.e. the areas, which are not accessible in the plugged-in condition) must be prevented. The plug connection can only be separated using a tool. This is achieved by using the unlocking protection "Plug protector" (Mounting accessory from Pepperl + Fuchs).
Manual electrical apparatus for hazardous areas
Electrical apparatus for potentially explosive atmospheres
$\langle \!$
94/9/EG
EN 60079-31:2009
Laws and/or regulations and standards governing the use or intended usage goal must be observed. Attach the connector fuse provided so that the connector cannot be unplugged without using tools. Only connections that are disconnected from the power supply may be unplugged.
No modifications must be undertaken on apparatus, which is operated in hazardous areas. Repairs to such apparatus are not permissible.
The apparatus must be protected from mechanical damage.
Precautions must be taken to prevent the rated voltage being exceeded by more than 40 % due to tran- sient disturbances.
The sensor must be protected against harmful UV radiation. This can be achieved by using the sensor indoors.
Set up the apparatus so that optical components cannot come into contact with direct sunlight.

Curves / Diagrams









www.pepperl-fuchs.com



4